

Trend Configuration

The *Trend Configuration Tool* in the *Admin Tab* allows the user to add, edit or configure trends. The tool also allows the end-user to create new trends or determine which units or parameters are to be shown on the *Trends Tab*, as seen in the right-hand side, upper right of **FIGURE ERROR! No text of specified style in document.-1**. A *Trend* group may be multi-scaled (each pen is rescaled 0-100% for visibility), made public, activated, given a default amount of data to display, and assigned a Reporting Group, as seen in the right-hand side, upper left of **FIGURE ERROR! No text of specified style in document.-1**. If an item is not listed in the *Tags*, the administrator may create a new *Tag*, then, return to *Trends Configuration* for monitoring, (see **ERROR! REFERENCE SOURCE NOT FOUND.** for more information on configuring tags).

Trends Administration

Current Trend Groups

☒ Show Public

Filter Reporting Group: None (N/A)

Unit 1 Opacity

Test Group1

Unit 1 Gases

Test2

landon test

Test Trend Group

Add

Delete

Unit 1 Gases

Name

Unit 1 Gases

Description

Gas Analyzers - Unit 1 - 8 Hr

☒ Is Multi-Scale

Default Time Span: 12 Hours

☒ Is Public

Reporting Group: None (N/A)

☒ Is Active

Load

(Generation Edited)

CO2

0

20

SO2 High

(High Range SO2)

0

100

SO2 Low

(Low Range SO2)

0

50

NOx High

(High Range NOx)

0

500

NOx Low

(Low Range NOx)

0

100

NOx Rate

(NOx Rate Calculation)

Add

Delete

Back

Save

Figure **ERROR! No text of specified style in document.-1** Trend Configuration