

Table 4 to Subpart UUUUU of Part 63 - Operating Limits for EGUs

As stated in [§ 63.9991](#), you must comply with the applicable operating limits:

<b>If you demonstrate compliance using . . .</b>	<b>You must meet these operating limits . . .</b>
PM CPMS	Maintain the 30-boiler operating day rolling average PM CPMS output determined in accordance with the requirements of § 63.10023(b)(2) and obtained during the most recent performance test run demonstrating compliance with the filterable PM, total non-mercury HAP metals (total HAP metals, for liquid oil-fired units), or individual non-mercury HAP metals (individual HAP metals including Hg, for liquid oil-fired units) emissions limitation(s).

[[81 FR 20197](#), Apr. 6, 2016]