

8.8.2 For CEMS:

- A written record of the procedures used for the required QA tests (i.e., daily calibration, linearity checks, RATAs, etc.);
- The procedures used to adjust the CEMS to ensure accuracy; and
- For units with add-on SO₂ or NO_x emission controls, a list of the parameters that are monitored during monitor outages to verify that the controls are working properly, and the acceptable values and ranges of the parameters.