

## Data Sub-Tab

The *Data Sub-Tab* is used to display current compliance data. The parameters will be plant specific. The timed averages will be programed by *Spectrum Systems, Inc.* and will display on the screen, as seen in **FIGURE ERROR! No text of specified style in document.-1.**

Events

Downtime

Data

Unit 1 Opacity

- 6 min opacity data 3 Parameters

Last Updated: 3h

400 Un-Acknowledged Events, In Compliance

SampleTime	Fans_On	Generation	Opacity
10/28/2015 7:42:00 AM	360	486	81
10/28/2015 7:36:00 AM	360	486	81
10/28/2015 7:30:00 AM	360	486	81
10/28/2015 7:24:00 AM	360	486	81
10/28/2015 7:18:00 AM	360	486	81
10/28/2015 7:12:00 AM	360	486	81
10/28/2015 7:06:00 AM	360	486	81

Unit 1 CEMS

- 15 min cems data 9 Parameters

Last Updated: 3h

SampleTime	CO2_%	Flow_kscfm	Generation_MW	NOx_High_ppm	NOx_Low_ppm	NOx_ppm	SO2_High_ppm	SO2_Low_ppm	Unit_On_Secs
10/28/2015 7:30:00 AM	10.54775	0	486.0611	81.7501	0	0	42.01325	0	900
10/28/2015 7:15:00 AM	10.54671	0	486.0643	81.72975	0	0	42.05667	0	900
10/28/2015 7:00:00 AM	10.54649	0	486.0415	81.70262	0	0	41.97798	0	900
10/28/2015 6:45:00 AM	10.54626	0	486.0415	81.69312	0	0	41.96441	0	900
10/28/2015 6:30:00 AM	10.54665	0	486.0448	81.69178	0	0	41.97527	0	900
10/28/2015 6:15:00 AM	10.54485	0	486.0611	81.71618	0	0	42.01054	0	900
10/28/2015 6:00:00 AM	10.54577	0	486.0431	88.50495	0	0	58.15489	0	900

Unit 1 Part 75

- Hourly cems data 10 Parameters

Last Updated: 4h

Cable Test

- Low NOx vs Cable Low NOX 2 Parameters

Last Updated: 3h

Hour test

- Low NOx vs Cable NOx 2 Parameters

Last Updated: 4h

Part 75 Test

- Test CEMS Data 3 Parameters

Last Updated: 4h

Daniel Unit 1

- Hourly CEMS Data 16 Parameters

Last Updated: 4h

test app e

- 3 Parameters

Last Updated: 4h

Figure Error! No text of specified style in document.-1 Data Sub-Tab