

## **Question 19.23**

**Topic:** Bias Adjustment Factors and RM Backup Monitoring

**Question:** Must a bias adjustment factor (BAF) be applied to data from Part 75 RM backup monitors, as described in Section 7.6.5 of Appendix A to Part 75?

**Answer:** No. Part 75 bias adjustment factors are derived from relative accuracy test data. Backup reference method monitoring systems are not required to undergo relative accuracy testing and therefore the data from these systems are not subject to the bias adjustment requirements of Section 7.6.5.

**References:** § 75.20(d)(3); § 75.22; Part 75, Appendix A, Section 7.6.5

**History:** First published in March 1995, Update #5; revised in 2013 Manual