Question 19.27

Topic: DAHS Verification for RM Backup Formulas

Question: For formulas that include signals from RM backup monitoring systems, is formula verification required?

Answer: Formula verification is recommended, but not required. ECMPS will independently recalculate the hourly emission rates and heat input values for hours in which RM backup monitoring systems are used, to ensure that the DAHS is programmed correctly.

References: § 75.20(d)(3); § 75.20(c)(10)

History: First published in March 1995, Update #5; revised in October 1999 Revised Manual; revised in 2013 Manual