

## Question 12.3

**Topic:** Monitoring Plan Requirements for DAHS Changes

**Question:** What are the requirements for assigning new system and component IDs for DAHS version upgrades and DAHS vendor or platform changes?

**Answer:** For minor DAHS upgrades (such as vendor patches) it is not necessary to change any monitoring system or component IDs. However, for DAHS vendor or platform changes you must close out the old DAHS component by adding an End date and hour to the existing <MonitoringSystemComponentData> records linking the old DAHS component to each monitoring system and then create a new <MonitoringSystemComponentData> record for each system pointing to the new DAHS component. You must use a new unique component ID that has never been previously used to define any other component of a monitoring system at that monitoring location.

**References:** § 75.53(g)(1)(iii)

**History:** First published in March 1995, Update #5; revised in March 2000, Update #12; revised in October 2003 Revised Manual; revised in 2013 Manual