

Question 18.1

Topic: New Unit Exemptions (from Monitoring Requirements)

Question: Which Acid Rain Program units are eligible for a new unit monitoring exemption under Title IV?

Answer: In accordance with the provisions of § 72.7 and § 75.2(b)(1), if a new unit serves a generator (or generators) with a total capacity of 25 MWe or less and burns only fuels with a sulfur content of 0.05 weight percent or less, then that unit would be exempt from Acid Rain monitoring requirements.

References: § 72.7, § 75.2(b)(1)

History: First published in Original March 1993 Policy Manual; revised May 1993, Update #1; revised in 2013 Manual