

## Question 26.1

**Topic:** Reporting Requirements for Hourly Stack Moisture

**Question:** Is hourly stack moisture reporting required?

**Answer:** Only sources using formulas that require moisture corrections are required to account for the stack gas moisture content. This may be done using a continuous moisture monitoring system, as described in §75.11 (b)(2) .

Alternatively, for units that combust coal, wood, or natural gas may use default moisture values in the emissions calculations, in lieu of reporting hourly moisture monitoring data---see §§ 75.11(b) and 75.12(b).

**References:** § 75.11(b) and § 75.12(b)

**History:** First published in October 1999 Revised Manual; revised in 2013 Manual