

### **Question 3.1**

**Topic:** Applicability

**Question:** Is a flue gas volumetric flow monitor required on a gas-fired or oil-fired unit?

**Answer:** A gas-fired unit or oil-fired unit subject to the Acid Rain Program does not need a flue gas volumetric flow monitor if the owner or operator reports SO<sub>2</sub> mass emissions using the procedures specified in Appendix D or uses the low mass emissions (LME) methodology in § 75.19. Gas-fired and oil-fired units subject to Subpart H also have options for monitoring NO<sub>x</sub> mass that do not require flow CEMS. These are outlined in § 75.71.

**References:** § 75.11(d)(2), § 75.19, § 75.71; Appendix D

**History:** First published in Original March 1993 Policy Manual; revised in October 1999 Revised Manual