

## **Question 28.2**

**Topic:** Part 75 Units Affected by AETB Requirements

**Question:** Which Part 75 units are subject to the requirements of ASTM D7036-04?

**Answer:** Part 75 units that either perform periodic CEMS RATAs or NO<sub>x</sub> emission rate testing are subject to the requirements of ASTM D7036-04. This includes all Part 75 units except for certain low mass emissions (LME) units under §75.19 that elect to use default NO<sub>x</sub> emission factors from Table LM-2 rather than performing fuel- and unit-specific NO<sub>x</sub> emission rate testing.

**References:**

**History:** First published in 2013 Manual