

## **Question 7.7**

**Topic:** Monitor Location -- Certification Requirements

**Question:** If a regular non-redundant backup monitoring system is certified at a particular unit or stack, can the certification be applied to other unit or stack locations?

**Answer:** No. A regular non-redundant backup monitoring system must be separately certified at each location where it is used to obtain data (see Question 7.1).

**References:** § 75.20(d)

**History:** First published in Original March 1993 Policy Manual; revised in October 1999 Revised Manual; revised in 2013 Manual