

## Question 1.1

**Topic:** Time-shared Analyzers

**Question:** If two individual probes (for example, where the probes are installed in two different ducts) share an analyzer, are they considered individual monitoring systems?

**Answer:** Yes. The minimum data capture requirements of § 75.10(d)(1) therefore apply to each system separately (i.e., a minimum of one cycle of operation (sampling, analyzing, and data recording) must be completed in each successive 15-minute interval, for each monitoring system).

**References:** § 75.10(d)

**History:** First published in May 1993, Update #1; revised in October 1999 Revised Manual