

Question 22.7

Topic: Unit/Stack EDRs

Question: Should all of the units, pipes and stacks involved in a common stack NO_x apportionment configuration be included together in the same quarterly report?

Answer: Yes. All stack or pipe-level and associated unit-level data should be contained in a single quarterly report.

References:

History: First published in March 2000, Update #12; revised in 2013 Manual