

Question 8.23

Topic: Peaking Unit Annual Flow RATA

Question: Peaking units are only required to do an annual flow RATA at normal load. Must units meet the definition of a peaking unit in Part 72 in order to qualify for this reduced testing?

Answer: Yes. Report the peaking unit status in the <MonitoringQualificationData> and <MonitoringQualPercentData> records of the monitoring plan.

References: Appendix B, Section 2.3

History: First published in October 1999 Revised Manual; revised in October 2003 Revised Manual; revised in 2013 Manual