

## **Question 8.34**

**Topic:** RATAs for Time-shared Systems

**Question:** Does the reference method have to be performed simultaneously at each monitored location when using a time-shared CEMS?

**Answer:** No. Although a RATA must be performed for each monitored location when a time-shared CEMS is used, only one monitored location at a time needs to be sampled by the reference method.

**References:**

**History:** First published in October 2003 Revised Manual; revised in 2013 Manual