

## Question 16.9

**Topic:** Operating Data for Monitoring in Multiple Stacks or Ducts

**Question:** What are the requirements for reporting operating data for a unit using CEMS in multiple stacks or ducts?

**Answer:** For any quarter in which the unit operates at all, operating data must be submitted for all hours in the quarter for both the unit and the stacks or ducts. If, during any unit operating hour, the damper to a particular stack or duct is completely closed and the monitors in the stack or duct are recording zero emissions, report an operating time of zero (0.00) for that stack or duct, indicating a non-operating status for the hour.

**References:** § 75.64

**History:** First published in March 1995, Update #5; revised in October 1999  
Revised Manual