

Question 19.26

Topic: Submission of Revised Monitoring Plans Containing RM Backup Systems

Question: When must a utility identify RM backup systems in a monitoring plan?

Answer: RM backup systems must be represented in the electronic monitoring plan prior to submitting the electronic data report for a calendar quarter in which the systems are used to report emissions data. Use the ECMPS Client Tool to add the backup RM systems to the monitoring plan. The monitoring plan changes and the quarterly emissions report may be submitted on the same date, provided that the monitoring plan revisions are made prior to submitting the emissions report.

References: § 75.20(d)(3), § 75.53(g), § 75.62(a)(1); ECMPS Monitoring Plan Reporting Instructions, Sections 1.0 and 8.0

History: First published in March 1995, Update #5; revised in October 1999 Revised Manual; revised in October 2003 Revised Manual; revised in 2013 Manual