

Question 19.19

Topic: Restrictions on Use of RM Backup Monitoring

Question: Is there any limit on the number of hours that RM backup monitoring system may be operated under Part 75?

Answer: The only restriction is that when the primary monitoring system is operating and not out-of-control, the primary system must be used for data reporting under Part 75.

References: § 75.20(d)(3); § 75.10(e), § 75.24

History: First published in March 1995, Update #5; revised in October 1999 Revised Manual; revised in 2013 Manual