

Question 22.8

Topic: Reporting of Hourly NO_x Emission Rate and Heat Input Rate Data

Question: How do I report hourly data for a common stack NO_x apportionment?

Answer: Report hourly NO_x emission rate and heat input rate data for a common stack NO_x apportionment at each location where NO_x emission rate and/or heat input rate is measured (i.e., at the main common stack, any secondary common stack(s), any common pipe(s) and each unit monitoring location), as you would for any other NO_x monitoring configuration. Report *only* the measured data. Do *not* report hourly apportioned NO_x emission rate values for the NO_x affected units.

References:

History: First published in March 2000, Update #12; revised in 2013 Manual