

## Question 8.8

**Topic:** NO<sub>x</sub> RATA

**Question:** May I perform a RATA of my NO<sub>x</sub> monitoring system if I'm not using normal burner configuration? For example, one pulverizer is down and therefore one bank of burners cannot be used.

**Answer:** No. All RATAs must be performed under normal operating conditions for the unit.

**References:** Appendix A, Section 6.5

**History:** First published in November 1993, Update #2; revised in 2013 Manual