

JDi  
Architects & Planners  
JDi-Architecture.com  
Macomb Twp, MI  
586.604.9343

[illegible]

\* WIND LOAD.....90 MPH (3 SECOND GUST)  
FLOOR JOIST LOADING CRITERIA.....EXT. DECK JOIST LOADING CRITERIA

<u>DECK LOADING:</u>	
LIVE LOAD	60 P.S.F.
DEAD LOAD	10 P.S.F.
TOTAL LOAD	70 P.S.F.
LIVE LOAD DEFLECTION L/360	
TOTAL LOAD DEFLECTION L/240	
<u>ROOF TRUSS LOADING CRITERIA (DIMENSIONAL SHINGLES)</u>	
TOP CHORD	LIVE LOAD 25 P.S.F.
	DEAD LOAD 17 P.S.F.
BOTT. CHORD	LIVE LOAD 0 P.S.F.
	DEAD LOAD 10 P.S.F.
	TOTAL LOAD 52 P.S.F.

ROOF TRUSS LOADING CRITERIA (DIMENSIONAL SHINGLES)		
TOP CHORD	LIVE LOAD	25 P.S.F.
	DEAD LOAD	17 P.S.F.
BOTT. CHORD	LIVE LOAD	0 P.S.F.
	DEAD LOAD	10 P.S.F.
	TOTAL LOAD	52 P.S.F.

LIVE LOAD DEFLECTION  $L/240$   
TOTAL LOAD DEFLECTION  $L/180$

**NOTE:**

1. ADD 20 P.S.F. TO BOTTOM CHORD LIVE LOAD FOR UNINHABITABLE ATTICS WITH STORAGE
2. ADD 40 P.S.F. TO BOTTOM CHORD LIVE LOAD FOR HABITABLE ATTIC TRUSSES.

1. ALL COMMON FRAMED FLOOR DECKS SHALL BE:  
2' x 10' - #2 HEM FIR, OR BETTER  
1' x 12' - #2 DUGLAS FIR, OR BETTER
2. ALL COMMON FRAMING LUMBER IS TO MEET THE FOLLOWING MINIMUM SPECIFICATIONS AT 15% MOISTURE CONTENT:
3. MATERIAL
 

	Fb(Ps)	E(Ps)	Fc(Ps) (PERP.)	E(Ps)
#2 SPRUCE PINE FIR	875	450	425	1,000,000
#2 HEM FIR	850	525	405	1,200,000
#2 DUGLAS FIR-LARCH (2X12)	850	500	625	1,600,000
4. ALL STRUCTURAL COMPOSITE LUMBER (LV/L, PSL) IS TO MEET THE FOLLOWING MINIMUM SPECIFICATIONS:
- APPLICATION:
 

	Fb(Ps)	Fc(Ps) (PARALLEL)	Fc(Ps) (PERP.)	E(Ps)
GIRDERS & BEAMS (LV/L)	2,400	2,510	750	1,900,000
GIRDERS & BEAMS (PSL)	2,900	2,900	750	2,000,000
RIMBOARDS (LSL)	2,700	1,400	N/A	1,300,000
COLUMNS (PSL)	1,400	2,500	435	1,800,000
5. ALL GLUE LAMINATED TIMBER (GLU-LAM) IS TO MEET THE FOLLOWING MINIMUM SPECIFICATIONS:
- APPLICATION:
 

	Fb(Ps)	Fc(Ps) (PARALLEL)	Fc(Ps) (PERP.)	E(Ps)
GIRDERS & BEAMS (LV/L, PSL)	2,400	1,700	740	1,700,000
COLUMNS (LSL)	1,600	1,550	560	1,300,000
6. OPEN W/ FLOOR THROUS:
 

	Fb(Ps)	
TOP & BOTTOM CHORDS	2,200	1.9E LUMBER
WEB MEMBERS	950	1.4E LUMBER
7. ALL JOIST ARE TO BE PRODUCED IN ACCORDANCE WITH THE AMERICAN PLYWOOD ASSOCIATION (APA) AND ENGINEERED WOOD ASSOCIATION (EWA) PERFORMANCE RATED JOIST STANDARDS REFERENCE TABLE #7 FOR APA / EWS CONSTRUCTION METHODS AND PROPERTIES AS RELATED TO BENDING STRENGTH, MOMENT CAPACITY, SHEAR CAPACITY, INTERMEDIATE / END REACTIONS ALONG WITH COEFFICIENT OF SHEAR DEFORMATION.

A. LONG LEG OF THE ANGLE SHALL BE PLACED IN A VERTICAL POSITION.

B. DEPTH OF REINFORCED UNITS SHALL NOT BE LESS THAN 8 IN. & ALL CELLS OF HOLLOW MASONRY UNITS SHALL BE GROUTED SOLID. REINFORCING BARS SHALL EXTEND NOT LESS THAN 8 INCHES INTO THE SUPPORT.

C. STEEL MEMBERS INDICATED ARE ADEQUATE TYPICAL EXAMPLES: OTHER STEEL MEMBERS MEETING STRUCTURAL DESIGN REQUIREMENTS MAY BE USED.

**FIRST FLOOR:** 936 SQUARE FEET

An architectural line drawing of a house's front elevation. The house features a gabled roof with a small semi-circular window in the gable. The main entrance is centered, featuring a door with a six-panel design, flanked by two columns and topped with a triangular pediment. To the right of the entrance are two tall, narrow windows, each with a six-panel design. The entire facade is covered in horizontal siding. A small set of steps leads up to the entrance.

**ADDRESS:**

**1707 FISCHER STREET  
DETROIT, MICHIGAN**

**Project:**  
**Plan 001 - Alden**  
**Colonial Revival Style Elevation**  
**1707 Fischer Street**  
**Detroit, Michigan**

**Worksheet description:**  
**General Notes**

**DO NOT SCALE DRAWINGS USE  
FIGURED DIMENSIONS ONLY**

Architectural drawings are given in strict confidence. No use, in part or whole, without prior written consent of Greatwater Homes is allowed. All rights are hereby reserved.

*project number*

drawn JD

checked JD

*approved* JD

issued for      date

review 2022-072

---

final review 2022-081

final	2022-08-2
current version	2022-08-2

final	2022-0922
-------	-----------

---

lot spec	2022-092
----------	----------

elect. update 2022-103

---

---

---

---

sheet

G-10

## Conclusion

---