

Authorised Program Officer (APO) approval process

APO approval Process

On requesting approval to be an APO, the following will need to be agreed by the APO in RIDS. APOs who have not been already approved by their Provider authority from their organisation, will require additional approval from the Victorian Senior Practitioner after the Provider Authority approval has been obtained.

The following are the APO requirements for new APOs via RIDS

To the APO requesting access

In requesting access as the Authorised Program Officer, you confirm that you have the competencies underlined below to undertake this role to the full requirements of the *Disability Act 2006*

You agree you are able and willing to:

- (a) authorise a regulated restrictive practice in accordance with the legislative requirements of the Disability Act
- (b) implement an NDIS behaviour support plan or, as the case requires, the treatment plan and supervised treatment order, in accordance with the *Disability Act* or *NDIS (Restrictive Practices and Behaviour Support) Rules 2018 Service Safeguards Act 2018*
- (c) act in a manner that is consistent with the *Charter of Human Rights and Responsibilities Act 2006 (Vic)* or the principles in the *Disability Act*
- (d) meet future training requirements for APOs
- (e) undertake future Victorian Senior Practitioner Directions

And you have a current working with children certificate.

You agree you have never:

- (f) been on the Disability Worker Exclusion Scheme List
- (g) been issued an exclusion by an NDIS worker screening unit
- (h) committed a prescribed offence within the meaning of the *Disability Service Safeguards Act 2018*
- (i) been subject of a banning order issued under section 73ZN of the *National Disability Insurance Scheme Act 2013 (Cth)*
- (j) been refused registration due to misconduct issues, or has had the person's registration not renewed, suspended or cancelled due to misconduct issues under the *Disability Service Safeguards Act 2018*
- (k) been deregistered under another Act (such as lost registration as a nurse practitioner)

On the agreement in RIDS by the APO, approval is required by the Provider Authority.

Provider Authority approval of APOs

The following is the email that the Provider Authority will receive as a notification for approval of their APO, at their disability service. Once the Provider Authority has approved the APO in RIDS, the Victorian Senior Practitioner will review for Approval.

Email to Provider Authority or the APO approver

Callum Murray has requested access to 24 Fishmongers Lane, Melbourne as an APO.

In authorising this request you confirm, on behalf of X - IT Test, that Andrea Shelton has the competencies underlined below to undertake the Authorised Program Officer role to the full requirements of the *Disability Act 2006*.

You agree the person is able and willing to:

- (a) authorise a regulated restrictive practice in accordance with the legislative requirements of the *Disability Act*
- (b) implement an NDIS behaviour support plan or, as the case requires, the treatment plan and supervised treatment order, in accordance with the *Disability Act* or *NDIS (Restrictive Practices and Behaviour Support) Rules 2018*
- (c) act in a manner that is consistent with the Charter of Human Rights and Responsibilities Act 2006 (Vic) or the principles in the *Disability Act*
- (d) meet future training requirements
- (e) undertake future Victorian Senior Practitioner Directions
- and the person has a working with children certification

You agree the person has never:

- (f) been on the Disability Worker Exclusion Scheme List
- (g) been issued an exclusion by an NDIS worker screening unit
- (h) been or committed a prescribed offence within the meaning of the *Disability Service Safeguards Act 2018*
- (i) been deregistered under another Act (such as lost registration as a nurse practitioner)
- (j) been a subject of a banning order issued under section 73ZN of the *National Disability Insurance Scheme Act 2013 (Cth)*
- (k) been refused registration due to misconduct issues, or has had the person's registration not renewed, suspended or cancelled due to misconduct issues under the *Disability Service Safeguards Act 2018*


Please open the To Do Items in RIDS to authorise or reject this request.

This person will not have access into RIDS until this request is authorised.

An approval email will be sent automatically to the Victorian Senior Practitioner for APOs who require approval by their Provider. APOs who already have prior approval from their provider, do not require additional Victorian Senior Practitioner approval.

The flowchart below highlights the process.

Flowchart of the APO approval process



See e-Business and RIDS access document

To receive this publication in an accessible format phone 9096 8427 using the National Relay Service 13 36 77 if required, or email victorianseniorpractitioner@dhhs.vic.gov.au

Authorised and published by the Victorian Government, 1 Treasury Place, Melbourne.

© State of Victoria, Department of Health and Human Services August 2020.

Available at <<https://www.dhhs.vic.gov.au/victorian-senior-practitioner>>



westcoat
SPECIALTY COATING SYSTEMS

MADE IN THE USA | SINCE 1981

4007 Lockridge Street • San Diego, CA 92102
800.250.4519 • westcoat.com

SECTION 09 97 23 CONCRETE AND MASONRY COATINGS

PART 1 — GENERAL

1.01 — SUMMARY

- A. ~~Section includes: Provide a complete a concrete floor system that meet the requirements for specific use indicated in the contract documents. Include all applicable substrate testing, surface preparation, and detail work.~~

1.02 — RELATED SECTIONS

- A. ~~Section 033000 — Cast In Place Concrete~~
- B. ~~Section 030130 — Maintenance of Cast In Place Concrete~~
- C. ~~Section 099656 — Epoxy Coatings~~

1.03 — SUBMITTALS

- A. ~~Submit under provisions of Section 013300.~~
- B. ~~Product Data: Submit manufacturer's product data sheets on each product and system to be used including:~~
 - ~~1. Preparation instructions and recommendations.~~
 - ~~2. Storage and handling requirements.~~
 - ~~3. Installation methods.~~
 - ~~4. Maintenance requirements.~~
- C. ~~Selection Samples: For each system specified, provide two samples, representing manufacturer's full range of colors.~~

1.04 — QUALITY ASSURANCE

- A. ~~All materials used on the stained concrete floor system shall be manufactured and provided by a single manufacturer to ensure compatibility and proper bonding.~~
- B. ~~Use adequate numbers of skilled workmen thoroughly trained and experienced in the necessary crafts and completely familiar with the specified requirements and methods needed for proper performance of the work of this section.~~
- C. ~~Contractor shall have a minimum of 3 years experience installing concrete floor coatings similar to that which is required for this project and who is acceptable to the manufacturer.~~
 - ~~1. Applicator shall designate a single individual as project foreman who shall be on site at all times during installation.~~
 - ~~2. Contractor must show and have QCA Qualified Contractor/Applicator paperwork from the manufacturer of the coating system.~~
- D. ~~Convene a pre-application meeting before the start of application of coating system. Require attendance of parties directly affecting work of this section, including: Architect, contractor, applicator, and authorized representative of the coating system manufacturer and interfacing trades. Review the following:~~
 - ~~1. Drawings and specifications affecting work of this section.~~
 - ~~2. Protection of adjacent surfaces.~~
 - ~~3. Surface preparation and substrate conditions.~~
 - ~~4. Application.~~
 - ~~5. Field quality control.~~
 - ~~6. Cleaning.~~
 - ~~7. Protection of coating system.~~
 - ~~8. Repair of coating system.~~
 - ~~9. Coordination with other work.~~

~~1.05 DELIVERY, STORAGE & HANDLING~~

- ~~— A. Delivery: Materials shall be delivered to the job site in sealed, undamaged containers. Each container shall be clearly marked with manufacturer's label showing type of material, color, and lot number.~~
- ~~— B. Storage: Store all materials in a clean, dry place with a temperature range in accordance with manufacturer's instructions~~
- ~~— C. Handling: Handle products carefully to avoid damage to the containers. Read all labels and Material Safety Data Sheets prior to use.~~

~~1.06 PROJECT SITE CONDITIONS~~

- ~~— A. Maintain environmental conditions (temperature, humidity, and ventilation) within the limits recommended by the manufacturer.~~
- ~~— B. All concrete should be tested for moisture before applying a seamless coating. If moisture emissions exceed 5 lbs/1000 square feet (ASTM F1869) or if the relative humidity (RH) exceeds 75% (ASTM F2170), see EC-15 Moisture Vapor Barrier product specification.~~
- ~~— C. Concrete must be at least 2500 psi.~~
- ~~— E. Concrete must be cured for a minimum of 28 days before coating is applied~~
- ~~— F. Schedule coating work to avoid excessive dust and airborne contaminants. Protect work areas from excessive dust and airborne contaminants during coating application.~~
- ~~— G. Before any work is started, the applicator shall examine all surfaces for any deficiencies. Should any deficiencies exist, the architect, owner or general contractor shall be notified in writing and any corrections necessary shall be made.~~

PART 2 — PRODUCTS

~~2.01 MANUFACTURERS~~

- ~~— A. Acceptable manufacturer: Westcoat Specialty Coatings; 4007 Lockridge Street, San Diego, CA 92102. Telephone 800-250-4519. Fax 619-255-7187. Website: www.westcoat.com.~~

~~2.02 MATERIALS~~

- ~~— A. As basis of design Westcoat 11-10 System (no substitutions will be accepted): A process of preparing exterior concrete and applying nano, water-based stain and sealer.~~

~~2.03 COMPONENTS~~

- ~~— A. 11-10 System: Acrylic concrete color and seal.~~
 - ~~1. Primer: EC-11 Water Based Epoxy 500 to 800 square feet per gallon.~~
 - ~~2. Topcoat: SC-10 Acrylic 200-400 square feet per gallon.~~
 - ~~3. WB Stain: SC-35 Water Based Stain 400-600 square feet per gallon.~~
 - ~~4. WB Polyurethane Sealer: SC-65SG Semi-Gloss Water Based Polyurethane 400-650 square feet per gallon.~~

~~2.04 ACCESSORIES~~

- ~~— A. Supplemental Materials:~~
 - ~~1. Patching materials shall be TC-29 Concrete Patch~~
 - ~~2. Concrete repairs can be made with TC-23 Mortar Mix as needed.~~
 - ~~3. Optional aggregate shall be CA-29 Mini Safe Grip, CA-30 Small Safe Grip, CA-31 Large Safe Grip, or other sand designed to meet the owners skid resistance requirements.~~
- ~~— Optional Topcoats:~~
 - ~~4. SC-65G WB Gloss Polyurethane may be used IN LIEU of SC-65SG Semi-Gloss when a low odor, solvent free, mar and chemical resistant gloss finish is required.~~
 - ~~5. SC-65F WB Flat Polyurethane may be used OVER the SC-65G Gloss or SC-65SG Semi-Gloss when low odor, solvent free, mar and chemical resistant flat finish is required.~~

PART 3 — EXECUTION

3.01 EXAMINATION

- ~~_____ A. Verification of Conditions.~~
- ~~_____ 1. Inspect all surfaces to receive stained concrete flooring. Concrete must be clean, dry and free of grease, paint, oil, dust, curing agents, laitance or any foreign material that will prevent proper adhesion.~~
- ~~_____ 2. Before starting work, report in writing to the authority having jurisdiction any unsatisfactory conditions.~~

3.02 SURFACE PREPARATION

- ~~_____ A. Prepare surfaces using methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.~~
- ~~_____ B. Power wash and power scrub the concrete to obtain a clean—~~
- ~~_____ uniform surface with a surface profile equal to a CSP of 3 as specified by ICRI.~~
- ~~_____ C. Clean surface as needed with TSP and/or degreaser then rinse completely and scrub several~~
- ~~_____ times with clean water.~~
- ~~_____ D. Rout and clean moving cracks and joints; patch with manufacturer's recommended concrete~~
- ~~_____ patch material.~~
- ~~_____ E. Repair any non-moving surface deviations with manufacturer's recommended patching~~
- ~~_____ material.~~

3.03 INSTALLATION

- ~~A. Install stain & topcoat in accordance with manufacturer's instructions.~~
- ~~B. Mix multi-component materials in accordance with manufacturer's instructions.~~
- ~~C. Use application equipment, tools, and techniques in accordance with manufacturer's instructions.~~
- ~~D. Uniformly apply coatings at spread rates and in number of coats to achieve specified coverage rates recommended by the manufacturer.~~
- ~~E. Broadcast aggregates in accordance with the specified system and manufacturer's instructions.~~
- ~~F. Adhere to all limitations, instructions, and cautions for stained concrete floor coating as stated in the manufacturer's published literature.~~

3.04 FIELD QUALITY CONTROL

- ~~_____ A. Verify coatings and other materials are as specified.~~
- ~~_____ B. Verify coverages of the system as work progresses. Areas found not to meet the required coverage rates shall receive additional material until specified coverage is attained.~~
- ~~_____ C. Manufacturer's representative shall provide technical assistance and guidance for surface preparation and application of coating systems.~~

3.05 PROTECTION AND CLEAN UP

- ~~_____ A. Installation areas must be kept free from traffic and other trades during the application procedure and cure time.~~
- ~~_____ B. Protect finished surfaces of coating system from damage during construction.~~
- ~~_____ C. Touch up, repair or replace damaged flooring system after substantial completion.~~
- ~~_____ D. Clean area and remove all debris upon completion of work. Dispose of empty containers properly according to current Local, State and Federal regulations.~~

3.06 MAINTENANCE

- ~~_____ A. Contractor shall provide to owner, maintenance and cleaning instructions for the floor system upon completion of work. Owner is required to clean and maintain the surfaces to maintain manufacture's warranty.~~

END OF SECTION

This guide specification has been prepared by Westcoat Specialty Coating Systems to assist design professionals in developing a project specific specification. This guide is a template that must be reviewed and adapted by specifiers to comply with project requirements. This guide specification is not to be copied directly into a project specification manual without review.