Adaptive Control System for HVAC Optimization Using LLM and Fuzzy Logic

Project Supervisor : **Dr. D. H. S. Maithripala**

Yapa W.S.P.Y.J.C.
E/20/452

Athukorala L.A.K.S.
E/20/028

Wijekoon W.M.M.K.
E/20/442

Aim

To design an **adaptive HVAC** control system that enhances **energy efficiency** and **indoor comfort** by integrating disturbance prediction with **dynamic fuzzy logic rules** generated using a Large Language Model (**LLM**).

Objectives

1. **To Analyze limitations** of static HVAC systems in high-demand environments (e.g., data centers).

2. **To Develop an LLM-enhanced fuzzy logic controller** to generate adaptive HVAC rules.

3. **To Validate system performance** through simulations and controlled experiments, evaluating key metrics such as:
    - Energy consumption
    - Thermal stability
    - Response time to environmental changes

4. **To Compare performance against traditional HVAC** systems under varying environmental conditions.

Intended Learning Outcomes

1. **Apply Large Language Models (LLMs)** to generate and refine fuzzy logic rules for control applications.
2. **Design and simulate an intelligent control system** using appropriate computational tools (e.g., MATLAB, Python).
3. **Evaluate the performance of HVAC** control systems based on energy efficiency, thermal stability, and adaptability.
4. **Improve project planning, teamwork, and technical reporting** through hands-on implementation and collaboration.

Introduction



Problem :

HVACs have **static rules, poor real-time adaptability**, and limited response to **dynamic workloads**.

They require **manual calibration**, and their efficiency declines with **changing** environmental and operational **conditions** over time.

Traditional HVAC systems in data centers **waste up to 38% of energy**

Reference :
Ni, J. and Bai, X. (2017). A review of air conditioning energy performance in data centers. Renewable and Sustainable Energy Reviews, 67, pp.625–640. doi:https://doi.org/10.1016/j.rser.2016.09.050.

IEA (2018). The Future of Cooling – Analysis - IEA. [online] IEA. Available at: https://www.iea.org/reports/the-future-of-cooling

Introduction

Solution :

We use a Large Language Model to generate fuzzy control rules dynamically, enabling **real-time adaptive HVAC response** to disturbances.



Reference : IEA (2018). The Future of Cooling—Analysis—IEA. [online] IEA. Available at: https://www.iea.org/reports/the-future-of-cooling

Introduction



Impact :

Designing an **adaptive**, **scalable**, and **energy-efficient** HVAC control system can reduce **energy consumption**, **enhance performance**, improve **thermal comfort**, and extend equipment lifespan.

Reference : IEA (2018). The Future of Cooling – Analysis - IEA. [online] IEA. Available at: https://www.iea.org/reports/the-future-of-cooling

Advantages

Category	Traditional	Fuzzy + LLM
Adaptability	static	Adaptive
Energy Efficiency	Moderate	High
Comfort	Fluctuate	Smooth
Handling & Tuning	Manual	Dynamic
Prediction	Absent	Present with LLM

Methodology

Design Phase
- Gathering information and Study traditional HVAC
- Use a Large Language Model (LLM) to generate and refine fuzzy logic rules based on patterns in temperature, load, etc.

Implementation Phase
- Simulate using MATLAB or Python
- Integrate LLM-generated rules into a fuzzy logic controller for real-time adaptive control.

Testing Phase
- Simulate different thermal conditions using historical data.
- Test system performance using a test bench

Evaluation Phase
- Evaluate system performance based on energy efficiency, thermal stability, and responsiveness.
- Compare results with conventional HVAC controls.

Software’s

Timeline

No	Task	Week												
		01	02	03	04	05	06	07	08	09	10	11	12	13
1	Brainstorming, Supervisor Meeting, and Finalizing Project Scope													
2	Literature Review													
3	Gathering Information and System Design													
4	LLM Integration and Initial Fuzzy Logic Setup													
5	Refining System Design and Rule Tuning													
6	Preparing For Mid Evaluation													
7	Start Simulations and Initial Testing													
8	Refinements and System Testing													
9	Final Testing and Report Finalization													
10	Final Submission and Demonstration													

PERADENIYA
ENGINEERING

Department of Mechanical Engineering
University of Peradeniya

References

1. Dev, P., Jain, S., Arora, P.K. and Kumar, H., 2021. Machine learning and its impact on control systems: A review. Materials Today: Proceedings, 47, pp.3744-3749.
2. Yang, Z., Ghahramani, A. and Becerik-Gerber, B. (2016). Building occupancy diversity and HVAC (heating, ventilation, and air conditioning) system energy efficiency. Energy, 109, pp.641–649. doi:https://doi.org/10.1016/j.energy.2016.04.099.
3. Ni, J. and Bai, X. (2017). A review of air conditioning energy performance in data centers. Renewable and Sustainable Energy Reviews, 67, pp.625–640. doi:https://doi.org/10.1016/j.rser.2016.09.050.
4. Adel Nadjaran Toosi and Rajkumar Buyya (2015). A Fuzzy Logic-Based Controller for Cost and Energy Efficient Load Balancing in Geo-distributed Data Centers. IEEE/ACM International Conference Utility and Cloud Computing. doi:https://doi.org/10.1109/ucc.2015.35.
5. Esrafilian-Najafabadi, M. and Haghighat, F., 2021. Occupancy-based HVAC control using deep learning algorithms for estimating online preconditioning time in residential buildings. Energy and Buildings, 252, p.111377.
6. Mendel, J.M. (2000). Uncertainty, fuzzy logic, and signal processing. Signal Processing, 80(6), pp.913–933. doi:https://doi.org/10.1016/s0165-1684(00)00011-6.
7. Office of Energy Efficiency & Renewable Energy (2024). Data Centers and Servers. [online] Energy.gov. Available at: https://www.energy.gov/eere/buildings/data-centers-and-servers.
8. IEA (2018). The Future of Cooling – Analysis - IEA. [online] IEA. Available at: https://www.iea.org/reports/the-future-of-cooling

Q&A

Department of Mechanical Engineering
University of Peradeniya

PERADENIYA
ENGINEERING