WEST VIRGINIA DIVISION OF FORESTRY
FIREWISE WEST VIRGINIA PROGRAM
WOODLAND HOME WILDFIRE HAZARD ASSESSMENT

Reset

Homeowner Name, Address & Phone:				Occupancy Status:		Property ID (Lot No.):	
Community Name & Location (if applicable):				Structure Type:		County:	
Evaluator Name(s):				Evaluation Date:		Photo(s) Taken:	
GPS Filename (if applicable):		Datum Used:		Latitude:	UTM Zone:	Easting:	
				Longitude:		Northing:	

Evaluate the home by considering site hazard, structure hazard and hazard reduction factors. Enter the appropriate rating for each factor, and calculate the category subtotal. Sum these categories and calculate the overall Wildfire Hazard Rating for the property; using this value, mark the associated risk/hazard level. Be sure to mark what actions were taken at the time of evaluation. NOTE: If completing form electronically, some values will be automatically calculated.

SITE HAZARD RATING:		Rating
ACCESS AND VISIBILITY: Can emergency personnel find and access this home?		
Driveway < 150 feet long	(0)	
Driveway > 150 feet with adequate turnaround	(3)	
Driveway > 150 feet with inadequate turnaround	(5)	
Average driveway width more than 16 feet	(0)	
Average driveway width less than 16 feet	(5)	
No overhead branches below 16 feet high	(0)	
Obstructing overhead branches below 16 feet	(5)	
No bridges or bridges with no restrictions	(0)	
Inadequate surface/bridges for emergency vehicles	(5)	
Road grade level or less than 10%	(0)	
Road grade over 10%	(5)	
No gate/non-locking gate	(0)	
Locked gate restricting access	(5)	
Address visible from road (on house/end of drive)	(0)	
Address not visible from the road or not found	(5)	
SURROUNDING TREES: Choose the predominant tree type within 30' of the home.		
No trees within 30 feet	(0)	
Hardwoods (trees with deciduous leaves)	(4)	
Mixed (Hardwoods and Conifers/Evergreens)	(7)	
Conifers/Evergreens (non-deciduous)	(10)	
LADDER FUELS: Can fire spread from surface to aerial fuels?		
Include low limbs, underbrush, vines, etc.	No (0) Yes (5)	
FUEL CONNECTION: Are ground fuels touching or within 3 feet of the home?		
Include ornamental shrubs, leaves, grass, weeds, mulch beds, etc.	No (0) Yes (5)	

Use best judgment in estimating these factors - actual measurements are not required.

		Rating
GROUND COVER: Choose the primary type ground cover within 30' of the home.		
Sand, gravel, etc. (non-combustible)	(0)	
Grasses, up to 6" tall (established yard)	(3)	
Grasses over 6" tall (broomsedge, heavy weeds, etc.)	(10)	
Herbaceous understory or forest leaf litter	(15)	
Shrubs w/leaves (include creeping or spreading, i.e. ground ivy)	(5)	
Shrubs w/needles (creeping/spreading, i.e spreading juniper)	(7)	
SLOPE OF PROPERTY: What is the average slope around the structure(s)?		
Gradual (0 -10%)	(0)	
Moderate (11 - 30%)	(5)	
Steep (over 30%)	(10)	
FIREWOOD, DEBRIS OR COMBUSTIBLES: Where are fuel 'jackpots' located?		
Include firewood piles, brush piles, stored lumber, outdoor furniture, etc.	None (0) Located more than 30' from structure (1) Located 3' to 30' from structure (5) Located 0 to 3 feet from structure (10)	
FLAMMABLE MATERIALS: Where are highly flammable materials stored?		
Include gas cans, gas grills, lawnmowers, pesticides, etc.	None/Unknown (0) Located more than 30' from structure (1) Located 3' to 30' from structure (5) Located 0 to 3 feet from structure (10)	
OTHER POTENTIAL HAZARDS: Are there any external fire hazards present?		
Include outbuildings, LP gas storage tanks, etc. within 30 feet of the structure	No (0) Yes (5)	
TOTAL SITE HAZARD RATING		0

STRUCTURE HAZARD RATING:		Rating
ROOFING MATERIALS: What is the roof covering of the home?		
Metal, Slate, Tile or Class A Shingles	(0)	
Roll roofing or non-rated roof material	(5)	
Wood (cedar shingles or shakes)	(15)	
FOUNDATION: What type of foundation does the home have?		
Enclosed (fireproof, i.e. concrete, metal)	(0)	
Enclosed with wood or vinyl sheeting	(5)	
Open-air foundation (piers, stilts, etc.)	(10)	
EXTERIOR WALLS: What is the predominant outer wall covering of the home?		
**Evaluator has option to zero out the Total Structure Hazard Rating value*	*Brick, Stone or Metal (0) Vinyl or Wood (5)	
VENTS AND EAVES: Are these areas protected from flying embers?		
Enclosed with plastic or metal screens	(0)	
Exposed wood, open soffits/fascia, or unscreened vents	(5)	
ATTACHMENTS: Are there any attachments to the structure(s)?		
Include decks, overhangs, fences, trellises, etc.	No (0) Yes (5)	
FUEL TRAPS: Any areas where leaves/debris can accumulate?		
Include window wells, under steps, foundation indents, etc.	No (0) Yes (5)	
TOTAL STRUCTURE HAZARD RATING		0

Use best judgment in estimating these factors - actual measurements are not required.

HAZARD REDUCTION FACTORS: (choose all that apply)		Rating
SITE		
Trees pruned up 6 feet within 30' of the home	(-1)	
Grass kept watered and short within 30' of the home	(-1)	
Leaves/needles raked within 30 feet of the home	(-2)	
3 feet of gravel or non-flammable material next to structure	(-3)	
STRUCTURE		
Regularly cleaned roof and gutters	(-1)	
Deck skirting non-flammable/screened behind to keep out debris	(-3)	
OTHER		
Firefighting equipment available (hose, ladder, rake, etc.)	(-1)	
Useable water supply nearby (pool, pond, hydrant, etc.)	(-3)	
TOTAL HAZARD REDUCTION FACTORS	**(-)**	0

CALCULATING THE WILDFIRE HAZARD RATING

SITE HAZARD RATING		STRUCTURE HAZARD RATING		HAZARD REDUCTION FACTORS		OVERALL WILDFIRE HAZARD RATING
0	+	0	+	0	-	= 0

*Note modifications to Hazard Ratings, recommendations, etc.

What does the Wildfire Hazard Rating number mean?

Using the Wildfire Hazard Assessment, the highest possible rating is 150 points. Homes in the wildland/urban interface can be divided into the following four risk/hazard categories. The evaluator's judgment of this home's rating is indicated below:

☐	LOW	Total Wildfire Hazard Rating 30 points or under
☐	MODERATE	Total Wildfire Hazard Rating is 31 - 60 points
☐	HIGH	Total Wildfire Hazard Rating is 61 - 90 points
☐	VERY HIGH	Total Wildfire Hazard Rating is 91 - 120 points
☐	EXTREME	Total Wildfire Hazard Rating is over 120 points

Evaluator Action(s):	☐	Discussed results with homeowner/occupant
	☐	Firewise literature left at home
	☐	Other: