

STORM AND POWER LOG

Vale Observatory / Plant Book III leaf 24 / private spur and dome circuits

TIME E.S.T.	SYSTEM	OBSERVATION
8:40 P.M.	PRIVATE SPUR	drifted shut; 18 in. at upper bend
9:31 P.M.	TELEPHONE	overhead pair lost beyond gatehouse
10:03:12 P.M. E.S.T.	MAINS	lights, dome motor, remote displays lost
10:03:14	S-2 REGULATOR	mechanical standard continued
10:05 P.M.	GENERATOR	started; 14 gal.; lights only
ALL NIGHT	PUBLIC ROAD	reported open to valley gate