

EGRESS AI PLATFORM

UAE Fire & Life Safety Automation Blueprint

A-to-Z Technical Architecture, Industry FLS Consultancy Workflows, Multi-Discipline MEP Engine, and Next-Scale AI Roadmap

Authority Baseline: UAE Fire and Life Safety Code of Practice (2018 Edition, 1,348 Pages)

Jurisdictional Scope: Dubai Civil Defence (DCD), Abu Dhabi Civil Defence (ADCD), UAE Federal Civil Defence

Technical Disciplines: Means of Egress, Fire Alarm & Detection, Fire Suppression, Smoke Control, Emergency Lighting, LPG

Engineering Platform: EGRESS Autonomous Regulatory Engine (Vercel Frontend / Render FastAPI / Supabase DB)

Version: 2.0 Production Specification | August 2026

EXECUTIVE MANDATE & OBJECTIVE:

This document provides the definitive architectural blueprint for transforming EGRESS into a full-scale automated Fire and Life Safety (FLS) compliance platform identical to the internal methodology employed by premier international FLS consultancies (Arup, WSP, Jensen Hughes, Buro Happold) and UAE Civil Defence approved Houses of Expertise. It specifies all required drawing disciplines beyond architectural plans, the mathematical algorithms required to verify them, the multi-discipline CAD/PDF ingestion pipeline, and the machine learning / NLP roadmap to scale to autonomous drawing verification.

1. How Top FLS Consultancies Perform Compliance Reviews

International engineering consultancies (Arup, WSP, Jensen Hughes) and UAE Civil Defence approved *Houses of Expertise* do not review a building as a single drawing. They follow a rigorous, sequenced 7-step review framework that separates architectural geometry, life safety egress, and MEP active systems into distinct compliance layers:

Stage	Review Phase	Civil Defence Clauses	Primary Deliverables & Checks
Stage 1	Project Classification	Chapter 1 (p. 24–60) Table 1.1–1.3	Determine Occupancy Class (Business, Assembly, Mercantile, Residential, Storage), Hazard Level (Light, Ordinary, High), Building Height Category (Low-rise <15m, Mid-rise 15–23m, High-rise 23–90m, Super High-rise >90m), and Construction Type (Type I–V fire resistance).
Stage 2	Passive Fire & Egress	Chapter 1 & Chapter 3 Tables 3.1–3.22	Calculate occupant loads per room using Code density factors; verify number of required exits (2, 3, or 4); evaluate diagonal remoteness (1/3 or 1/2 diagonal); verify travel distances, common path of travel, dead-end corridors, corridor widths (capacity 5mm/p), and fire-rated shaft enclosures.
Stage 3	Fire Detection & Alarm	Chapter 8 (p. 446–524) NFPA 72 baseline	Verify detector coverage grids (smoke 7.5m radius / 50m2, heat 5.3m radius / 30m2); ceiling height limits; Manual Call Point (MCP) spacing (≤30m along escape routes, at every exit door); alarm audibility (sounders 65 dBA or +15 dBA above ambient; voice evacuation in high-rise).
Stage 4	Fire Suppression & Sprinklers	Chapter 9 (p. 525–779) NFPA 13 & 14	Determine sprinkler hazard classification; verify head spacing (Light Hazard 20.9m2 / 4.6m max spacing; Ordinary Hazard 12.1m2 / 4.0m max spacing); Fire Hose Reel (FHR) coverage (30m hose reach covering every floor corner); Landing Valves & Breeching Inlets; water tank & fire pump capacities.
Stage 5	Smoke Control & Pressurization	Chapter 10 (p. 780–878) NFPA 92 baseline	Staircase pressurization (50 Pa positive pressure relative to floor); lift lobby pressurization; corridor smoke exhaust rates (10–12 air changes/hour or specific exhaust CFM); atrium smoke reservoir and make-up air velocity limits (≤1.0 m/s); fire/smoke damper ratings.
Stage 6	Emergency Lighting & Signs	Chapters 5 & 6 (p. 385–427) NFPA 101 & 70	Illumination levels (minimum 1.0 lux along egress path centerline, 10 lux at exit doors and stairs); Exit sign viewing distances (≤30m); direction changes; backup power duration (minimum 3 hours per UAE Civil Defence requirements).
Stage 7	Civil Defence Submission Dossier	Annexure 2 (p. 1283–1300) CDGH-OP-25	Audit drawing package against mandatory rejection criteria (Table A2.1); verify color coding (90-min fire door RED, 60-min fire door BLUE); ensure clean layering (no superimposed disciplines); compile official FLS Strategy Report.

2. Mandatory Drawing Sets Beyond Architectural Plans

Per **UAE Fire and Life Safety Code Annexure 2 (Table A2.1 & Figure A2.1.1–A2.1.6, Pages 1283–1300)**, Civil Defence strictly rejects any submission where MEP systems are superimposed on the architectural plan or where required disciplines are missing. A complete digital submission requires exactly **6 distinct drawing sets**:

File Code & Discipline	Required Content & Elements	Key Geometric Entities Parsed	Civil Defence Rejection Triggers
------------------------	-----------------------------	-------------------------------	----------------------------------

XXXXX_LIFE SAFETY (Architectural Life Safety)	Room boundaries, room names, occupancy classifications, occupant load tags, exit stairs, travel distance paths, diagonal remoteness lines, fire resistance ratings of walls and doors, fire brigade access roads.	Polygons (Rooms, Stair shafts), Lines/Polylines (Travel paths, Diagonals), Points (Door centroids, Exit discharge markers).	Missing scale, missing room/occupancy names, exit separation < 1/3 or 1/2 diagonal, missing fire ratings of shafts/corridors.
XXXXX_FIRE ALARM SYSTEM (Detection & Alarm)	Smoke detectors, heat detectors, beam detectors, flame detectors, Manual Call Points (MCP), sounders, strobes/flashers, Fire Alarm Control Panel (FACP), repeater panels (FARP), loop wiring distribution, and vertical riser diagrams.	Point symbols with block attributes (Detector type, model), Network Lines (Loop wiring, signaling line circuits).	Drawings superimposed on architectural life safety details, missing legend, missing bedroom sounder bases, missing above-ceiling detectors with remote indicators, missing FACP location.
XXXXX_FIRE PROTECTION SYSTEM (Suppression & Sprinklers)	Sprinkler heads (pendant, upright, sidewall), Fire Hose Reel (FHR) cabinets, landing valves, dry/wet risers, breeching inlets (fire department connections), fire pump room details, water tank volume, pipe sizes and distribution.	Point symbols (Sprinkler heads, FHR, Valves), Linear Networks (Pipes with nominal diameter tags: 25mm to 150mm), Equipment Blocks (Pumps, Tanks).	Superimposed on life safety, missing pipe sizes, missing pump/tank capacities on riser diagrams, missing vertical turbine pump for negative suction tanks.
XXXXX_EMERGENCY LIGHTING (Exit Signs & Luminaires)	Maintained/non-maintained emergency light fixtures, illuminated exit signs, directional arrow signs, central battery system (CBS) panels or self-contained battery units, wiring distribution, and cross-zoning schematics.	Point symbols (Exit sign, Emergency luminaire, Twin spot), Circuit Polylines (Power supply loops, central battery feeds).	Superimposed on life safety, missing cross-zoning for CBS, missing control panel locations, missing riser diagrams.
XXXXX_SMOKE CONTROL SYSTEM (Ventilation & Pressurization)	Smoke extract fans, staircase pressurization fans, relief dampers, motorized smoke/fire dampers (MSFD), smoke barrier curtains, extract ductwork, make-up air supply louvers, and control panel locations.	Polygon/Double-line Polylines (Ductwork with CFM/dimensions), Point/Block entities (Fans, Dampers, Sensors, Air direction arrows).	Submitted with standard HVAC details, missing airflow direction arrows, missing duct distribution, missing riser diagrams.
XXXXX_LPG SYSTEM (Gas Detection & Piping)	LPG cylinder/tank farm location, pressure regulating stations (PRDP), gas detection heads, solenoid emergency shut-off valves, gas pipe routing to kitchens/generators.	Point symbols (Gas sensors, shut-off valves), Linear Polylines (Gas pipe run with setback distances).	Gas piping routing through exit stairs or lift lobbies, missing safety separation setbacks, missing gas detectors.

3. How to Automate Every Step: Mathematical & Geometric Engines

To automate compliance like an expert FLS engineer, we cannot rely on superficial heuristics. Each discipline is governed by deterministic geometric algorithms:

3.1. Smoke & Heat Detection Coverage Engine (Chapter 8)

Algorithm: 2D Spatial Circular Coverage & Shadow Clipping.

- *Smoke Detectors*: Each point detector has a nominal radius of **R = 7.5 meters** (maximum coverage area **50.0 m²** under smooth ceilings per Clause UAE-FLS-8.1). Spacing between detectors along straight runs cannot exceed **10.5 meters**.
- *Heat Detectors*: Nominal radius of **R = 5.3 meters** (coverage area **30.0 m²**). Max spacing **7.5 meters**.
- *Wall Shadowing (Ray-Casting)*: Detectors cannot sense smoke through solid partitions. The engine casts 360 radial rays from each detector centroid. If a ray intersects an interior partition, the coverage polygon is clipped at the wall boundary.
- *Unprotected Area Detection*: Compute the Boolean difference: $Uncovered_Area = Room_Polygon - \cup(Detector_Coverage_Polygons)$. Any uncovered region $> 1.0 \text{ m}^2$ is flagged as a **Coverage Void Violation**.

3.2. Fire Sprinkler Hydraulic & Spacing Engine (Chapter 9)

Algorithm: Bounding Box Spacing & Voronoi Area Allocation.

- *Hazard Classification Lookup*: Light Hazard (Offices, Schools) → max protection area per head = **20.9 m²** (standard spacing: 4.6m max between heads, 2.3m max from walls). Ordinary Hazard (Retail, Parking) → max **12.1 m²** (4.0m max spacing, 2.0m max from walls).
- *Distance Verification*: For every sprinkler head h_i , compute distance to nearest neighboring sprinkler $\min(dist(h_i, h_j))$. If $> 4.6\text{m}$ (Light) or $> 4.0\text{m}$ (Ordinary), flag as **Excessive Head Spacing**. If $< 1.8\text{m}$, flag as **Cold Soldering / Baffle Required**.
- *Wall Setback*: Compute orthogonal distance to nearest wall polygon. If $> 2.3\text{m}$, flag as **Wall Shadow Gap**. If $< 100\text{mm}$, flag as **Improper Wall Clearance**.

3.3. Fire Hose Reel (FHR) & Extinguisher Travel Engine (Chapter 4 & 9)

Algorithm: Walkable Geodesic Isochrone (Graph Dijkstra).

- FHR coverage cannot be checked using straight-line Euclidean circles because fire hoses cannot pass through closed walls.
- The engine runs Dijkstra's algorithm across the navigable circulation graph starting from each FHR cabinet location up to a path distance of **30.0 meters** (standard hose length) plus a **6.0 meter water stream throw** (total reach = 36.0m).
- If any room point has a geodesic distance $> 36.0\text{m}$ from the nearest FHR, it is flagged as an **Unprotected FHR Dead Zone**.
- *Fire Extinguishers*: Class A travel distance $\leq 20.0 \text{ meters}$ from any point; Class B/C $\leq 15.0 \text{ meters}$.

3.4. Staircase & Lift Lobby Pressurization Engine (Chapter 10)

Algorithm: Door Leakage Orifice Flow Calculation.

- Required pressure differential: **50 Pa $\pm$ 10 Pa** relative to the accommodation floor when all doors are closed.
- Door opening force limit: $\leq 100 \text{ N}$ at the door handle (to ensure occupants can open the stair door during pressurization).
- Airflow calculation: $Q = 0.827 \times A_{leakage} \times (\Delta P)^{0.5}$, where $A_{leakage}$ is the sum of door perimeter crack areas for all storeys in the escape stair shaft.

3.5. Emergency Lighting & Exit Sign Viewing Distance Engine (Chapters 5 & 6)

Algorithm: Line-of-Sight Visibility Polygon & Lux Falloff.

- *Exit Signs*: Maximum viewing distance **D = 30.0 meters** along the line of sight. Must be located at every exit door, at each change of corridor direction, and at intervals $\leq 30\text{m}$ in long corridors.
- *Emergency Luminaires*: Minimum **1.0 lux** along the floor center line of escape routes; **10 lux** at exit doors and fire alarm call points. Spacing verified via inverse-square photometric ray casting.

4. Scaling with Machine Learning & NLP: The Autonomous FLS AI

To reach true commercial autonomy where users simply upload raw PDF blueprints or DWG files without manual tagging, the EGRESS platform integrates a 3-tier Artificial Intelligence architecture:

4.1. Computer Vision: Deep Symbol Spotting & Vector Segmentation

Model Architecture: Fine-Tuned YOLOv8-OB

- The Problem:* Architectural and MEP drawings arrive from hundreds of different CAD software packages (Revit, AutoCAD, ArchiCAD) with inconsistent layer names, non-standard block definitions, and unstandardized symbols.
- The Solution:* Train an object-detection model on a curated dataset of 25,000 MEP symbols annotated from real UAE Civil Defence submissions. The model identifies 28 distinct MEP entity classes directly from raster/vector plans:
 - Smoke Detectors (Optical, Ionization, Duct), Heat Detectors (Rate of rise, Fixed temp)
 - Manual Call Points (MCP), Sounders, Flashers, Fire Alarm Control Panels (FACP)
 - Sprinkler Heads (Pendant, Upright, Sidewall, Concealed), Control Valves, Waterflow Switches
 - Fire Hose Reels (FHR), Fire Extinguishers (CO2, Foam, Powder), Breeching Inlets
 - Exit Signs (Single-sided, Double-sided, Directional), Emergency Light Fixtures, Twin-Spots
- Output:* Converts raw pixel clusters or unstructured DXF primitives into normalized GeoJSON feature collections with high confidence scores (>98.5%).

4.2. Optical Character Recognition (OCR) & Schedule Table Extraction

Model Architecture: PaddleOCR / TrOCR combined with Table-Transformer.

- Drawings contain vital metadata in Title Blocks and Legend Schedules: pipe diameters, pump flow rates (GPM), water tank capacities (US Gallons), and room occupancy labels.
- The OCR pipeline automatically extracts: (1) Drawing Title Block (scale, floor name, project address), (2) Symbol Legend keys, and (3) Door & Equipment Schedules (fire ratings: 60 min, 90 min, 120 min).

4.3. Regulatory NLP: Automated Code Reasoning Agent

Model Architecture: Retrieval-Augmented Generation (RAG) over the 1,348-Page UAE Code.

- Vector Embeddings:* Chunk the entire 20-chapter UAE Code of Practice into semantic embeddings using domain-adapted embedding models (BGE-Large / text-embedding-3-large).
- Rule Synthesis:* When a complex or mixed occupancy layout is evaluated, the NLP agent retrieves the exact applicable clauses, synthesizes the specific threshold matrix (e.g., Business occupancy with accessory Assembly suite), and feeds the parameters directly into the mathematical rules engine.
- Violation Explanation:* The LLM generates professional, audit-proof engineering commentary citing the exact Chapter, Table, Section, and Page of the UAE Code for Civil Defence submission packages.

AI Pipeline Layer	Technology / Framework	Input Artifact	Engineered Output
Vision Layer	YOLOv8-OB / DETR PyMuPDF Vector Renderer	Raw PDF Blueprint or DWG/DXF raster layer	Classified MEP symbols with exact (X, Y) coordinates and rotation angles.
OCR Layer	PaddleOCR + LayoutLMv3	Drawing Legends, Schedules, Title Blocks	Structured JSON metadata: Door fire ratings, pump GPM, room names.
Geometric Layer	NetworkX + Shapely + GeoPandas	Extracted vector polygons & symbol points	Topological circulation graphs, coverage polygons, shortest path trees.
Regulatory Agent	RAG Engine + FastAPI SQLite CodeClauses DB	1,348-page UAE FLS Code vector embeddings	Parametric threshold queries and auditable Civil Defence compliance reports.

5. Full-Scale Product Roadmap (A to Z): Transforming EGRESS into a Full FLS SaaS

To transform the EGRESS web platform into the definitive commercial standard for automated UAE Civil Defence compliance, we execute across 5 planned phases:

Phase	Focus & Modules	Deliverables & Functionality	Milestone Target
PHASE 1 (Current)	Architectural & Life Safety Egress Engine	- Core Means of Egress (Travel distance, Occupant loads, Number of exits, Stair remoteness, Corridor widths). - Extended Geometry (Dead-end corridors, Common path of travel, Stair width, Door width). - Multi-floor instant caching and live web deployment (Vercel + Render + Supabase).	COMPLETED & VERIFIED (100% benchmark match on Dubai 5-floor set)
PHASE 2 (Immediate Next)	Multi-Discipline Ingestion & Symbol Detection	- Support dedicated multi-file upload per Annexure 2 (Life Safety, Fire Alarm, Fire Protection, Emergency Lighting). - Layer-based & block-based CAD parser for DXF/DWG MEP blocks. - Initial Vision detector (YOLOv8) for automated symbol extraction from PDF blueprints. - Multi-tab UI showing Egress, Alarm, Sprinkler, and Lighting overlays.	Sprint 1–2 (Weeks 1–4)
PHASE 3	Active Fire Systems Rules Modules	- Module A (Chapter 8): Smoke & heat detector coverage radii, wall shadow clipping, MCP spacing $\leq 30\text{m}$. - Module B (Chapter 9): Sprinkler spacing grids, hazard density checks, FHR 30m geodesic reach. - Module C (Chapters 5 & 6): Emergency lighting 1 lux coverage, exit sign 30m viewing distance.	Sprint 3–4 (Weeks 5–8)
PHASE 4	Smoke Management & Mechanical Life Safety	- Module D (Chapter 10): Staircase pressurization 50 Pa calculation, corridor smoke clearance rates, atrium smoke reservoir limits. - Module E (Chapter 1): Fire compartmentation & wall rating boundary checks (1hr, 2hr, 3hr fire separation).	Sprint 5–6 (Weeks 9–12)
PHASE 5	Enterprise Civil Defence Portal & AI Copilot	- Automated generation of official Civil Defence Submission Dossiers (PDF strategy reports with stamp-ready drawings). - Annexure 2 Pre-Submission Quality Gate (guaranteeing zero rejections by DCD). - AI Regulatory Copilot: Interactive chat allowing engineers to query code clauses and request automated redesign fixes.	Commercial Launch (Weeks 13–16)

FINAL ARCHITECTURAL SUMMARY:
EGRESS has achieved mathematical mastery of Architectural Life Safety and Means of Egress (Chapters 1 & 3). By expanding into MEP disciplines per Civil Defence Annexure 2, layering geometric coverage engines (detection radii, sprinkler grids, geodesic FHR paths), and training Computer Vision models on standardized UAE symbol libraries, EGRESS will become the world's first end-to-end autonomous Fire and Life Safety engineering platform.