**GUARDFLOW TECH**

Export brand of Hangzhou Dingsheng Wangjie Machinery Co., Ltd.

# Third-Party Test Report - Summary

One-page extract of the full Chinese certificate. The original is available on request.

## Key Results - Independently Tested

| | |
|---|---|
| Horizontal throw (solid stream, 30 deg elevation) | **155.0 m at 152.6 L/s** |
| Vertical reach (70 deg elevation) | **110.0 m at 155.3 L/s** |
| Rated working pressure | **1.6 - 3.7 MPa** |
| Pump duty (diesel-driven centrifugal unit) | **77.5 L/s at 3.8 MPa** |
| Start-up to rated duty | **45.0 s** |
| Continuous operation | **stable, no flow interruption** |
| Water-tightness (pressure parts) | **no leakage after test** |
| Jet interval time | **30.0 s** |

## Test Authority and Scope

| | |
|---|---|
| Laboratory | Shanghai Fire Research Institute, Ministry of Emergency Management (PRC) |
| Product tested | Long-range fire monitor / firefighting system, model YKPSKD1.6-3.7/75 |
| Test basis | Q/DSWJ 001-2025 (long-range fire monitor system); GB 19156-2019 (fire monitors) |
| Test type | Commissioned (client-commissioned) verification test |
| Date of test | 9 April 2026 |
| Verdict | All inspected items passed (see full report) |

### Note on the product series

The figures above are for the /75 model. A larger 160-series unit is in factory field service with throws beyond 200 m (see the enclosed field-test video). Series selection depends on facade height, water supply and site access - we will recommend the right unit for your case.

Jasmine
GuardFlow Tech
Email: jasmine@guardflowtech.com