VERIFIED CHECKLIST

What runs, and what proves it

29/32
capabilities verified

Every row was driven from another process over REST API v2 or oBIX, then confirmed from outside the station with an independent protocol client.

✓ verified - reproduced, and the evidence is named

○ blank - not verified, and nothing in these documents claims it

PART 1 — THE STATION PUBLISHES POINTS

18 / 21 verified

#	Capability	Protocol	Executed over	✓	Evidence
1.1	Enable the driver network	BACnet/IP	REST mod	✓	parent reads enabled = true, {ok}
1.2	Enable the IP port	BACnet/IP	REST mod	✓	child port reads enabled = true
1.3	Bind the port link to a real NIC	BACnet/IP	oBIX PUT (enum names)	✓	adapter / adapterId / ipAddress resolve to the physical NIC
1.4	Server answers a Who-Is from another host	BACnet/IP	unicast UDP 47808	✓	I-Am returns the station device instance
1.5	Create an export descriptor	BACnet/IP	REST add	✓	the object appears in the export table
1.6	Write pointOrd (a BOrd slot)	BACnet/IP	oBIX PUT	✓	slot read-back shows the source ord; REST rejects this slot
1.7	Write objectId and let the component rename	BACnet/IP	REST mod	✓	the component name changes to the object name
1.8	Create an export point	oBIX	REST add	✓	the point appears under the export container
1.9	Write the point slot (a BOrd slot)	oBIX	oBIX PUT	✓	binding resolves; REST rejects this slot
1.10	Read the export from outside	oBIX	GET /obix/config/...	✓	the export returns its value and type
1.11	Create a slave point	Modbus TCP slave	REST cp	✓	the copy carries a real proxy extension
1.12	Bind the register	Modbus TCP slave	REST mod on dataAddress	✓	the point shows the intended register
1.13	Read the register from outside	Modbus TCP slave	Modbus FC03	✓	the returned word equals the point value
1.14	Write the register from outside	Modbus TCP slave	Modbus FC06	✓	the slave point follows the written value
1.15	Component create / copy / rename / remove	all	REST v2 add cp rename remove	✓	40-case suite, all passed
1.16	Multi-operation edits in one request	all	REST v2 /api/batch	✓	one POST, 11 operations applied atomically
1.17	Facet edit and read-back	all	REST v2 mod with N=facets	✓	the value renders with the new facet
1.18	Program source upload and compile	all	REST v2 /api/program/*	✓	compile response accepted

Verified checklist

continued

#	Capability	Protocol	Executed over	✓	Evidence
1.19	Read the exported object with ReadProperty	BACnet/IP	BACnet ReadProperty	○	
1.20	Write through an oBIX export (<value>/set/)	oBIX	oBIX PUT	○	
1.21	SNMP agent exports	SNMP	—	○	

PART 2 — THE STATION COLLECTS POINTS — **11 / 11 verified**

#	Capability	Protocol	Executed over	✓	Evidence
2.1	Create a client network	Modbus TCP	REST add + mod	✓	network reads enabled = true, {ok}
2.2	Create a client device	Modbus TCP	REST add	✓	device appears with its address slots
2.3	Set address, port and unit id	Modbus TCP	REST mod	✓	slots read back the values written
2.4	Create a point with its proxy extension	Modbus TCP	REST add with PROXY	✓	proxyExt is ModbusClientNumericProxyExt, not a null proxy
2.5	Set the register data type	Modbus TCP	oBIX PUT (enum name)	✓	dataType = integerType, enum slot resolves
2.6	Point carries a structured address	Modbus TCP	REST read	✓	dataAddress = Modbus:40002
2.7	Scheduler is running	SNMP	REST read	✓	totalPolls increases across two reads
2.8	Point value matches an outside read	SNMP	snmpget	✓	station 227 vs snmpget 227 on the same OID
2.9	Point value matches an outside read	Modbus TCP	Modbus FC03	✓	outside FC03 read of the bound holding register returns the word the point reads
2.10	Point collected and driven from outside	BACnet/IP	BACnet ReadProperty	✓	ReadProperty from another host returns the exported object present value
2.11	Point collected from an oBIX server	oBIX	GET /obix/config	✓	the remote oBIX server answers /obix/config and the point follows its value

HOW A ROW EARNS ITS MARK

— **REST / oBIX rows**
the slot read-back after the write, not the write's own response.

— **Outside rows**
a protocol frame captured or decoded from a client that does not share the station's code: Modbus FC03/FC06, BACnet Who-Is and ReadProperty, snmpget.

— **Counter rows**
two reads of the same counter, separated by a known interval.

A slot that reports success without producing the observation is not evidence, so it never turns a blank row into a check mark.