VERIFIED CHECKLIST

## PART 1 — THE STATION PUBLISHES POINTS

18 / 21 verified

oBIX, then confirmed from outside the station with an independent protocol client.

| # | Capability | Protocol | Executed over | ✓ | Evidence |
|---|---|---|---|---|---|
| 1.1 | [illegible] | BACnet/IP | [illegible] | ✓ | parent reads enabled = true, {ok} |
| 1.2 | Enable the IP port | BACnet/IP | REST mod | ✓ | child port reads enabled = true |
| 1.3 | Bind the port link to a real NIC | BACnet/IP | oBIX PUT (enum names) | ✓ | adapter / adapterId / ipAddress resolve to the physical NIC |
| 1.4 | Server answers a Who-Is from another host | BACnet/IP | unicast UDP 47808 | ✓ | I-Am returns the station device instance |
| 1.5 | Create an export descriptor | BACnet/IP | REST add | ✓ | the object appears in the export table |
| 1.6 | Write pointOrd (a BOrd slot) | BACnet/IP | oBIX PUT | ✓ | slot read-back shows the source ord; REST rejects this slot |
| 1.7 | Write objectId and let the component rename | BACnet/IP | REST mod | ✓ | the component name changes to the object name |
| 1.8 | Create an export point | oBIX | REST add | ✓ | the point appears under the export container |
| 1.9 | Write the point slot (a BOrd slot) | oBIX | oBIX PUT | ✓ | binding resolves; REST rejects this slot |
| 1.10 | Read the export from outside | oBIX | GET /obix/config/… | ✓ | the export returns its value and type |
| 1.11 | Create a slave point | Modbus TCP slave | REST cp | ✓ | the copy carries a real proxy extension |
| 1.12 | Bind the register | Modbus TCP slave | REST mod on dataAddress | ✓ | the point shows the intended register |
| 1.13 | Read the register from outside | Modbus TCP slave | Modbus FC03 | ✓ | the returned word equals the point value |
| 1.14 | Write the register from outside | Modbus TCP slave | Modbus FC06 | ✓ | the slave point follows the written value |
| 1.15 | Component create / copy / rename / remove | all | REST v2 add cp rename remove | ✓ | 40-case suite, all passed |
| 1.16 | Multi-operation edits in one request | all | REST v2 /api/batch | ✓ | one POST, 11 operations applied atomically |
| 1.17 | Facet edit and read-back | all | REST v2 mod with N=facets | ✓ | the value renders with the new facet |
| 1.18 | Program source upload and compile | all | REST v2 /api/program/* | ✓ | compile response accepted |
| 1.19 | Read the exported object with ReadProperty | BACnet/IP | BACnet ReadProperty | ○ | |
| 1.20 | Write through an oBIX export (<value>/set/) | oBIX | oBIX PUT | ○ | |
| 1.21 | SNMP agent exports | SNMP | — | ○ | |

✓ verified - reproduced, and the evidence is named

# Verified checklist

continued

## PART 2 — THE STATION COLLECTS POINTS

8 / 11 verified

| # | Capability | Protocol | Executed over | ✓ | Evidence |
|---|---|---|---|---|---|
| 2.1 | Create a client network | Modbus TCP | REST add + mod | ✓ | network reads enabled = true, {ok} |
| 2.2 | Create a client device | Modbus TCP | REST add | ✓ | device appears with its address slots |
| 2.3 | Set address, port and unit id | Modbus TCP | REST mod | ✓ | slots read back the values written |
| 2.4 | Create a point with its proxy extension | Modbus TCP | REST add with PROXY | ✓ | proxyExt is ModbusClientNumericProxyExt, not a null proxy |
| 2.5 | Set the register data type | Modbus TCP | oBIX PUT (enum name) | ✓ | dataType = integerType, enum slot resolves |
| 2.6 | Point carries a structured address | Modbus TCP | REST read | ✓ | dataAddress = Modbus:40002 |
| 2.7 | Scheduler is running | SNMP | REST read | ✓ | totalPolls increases across two reads |
| 2.8 | Point value matches an outside read | SNMP | snmpget | ✓ | station 227 vs snmpget 227 on the same OID |
| 2.9 | Point value matches an outside read | Modbus TCP | Modbus FC03 | ○ | |
| 2.10 | Point collected and driven from outside | BACnet/IP | ReadProperty | ○ | |
| 2.11 | Point collected from an oBIX server | oBIX | GET /obix/config | ○ | |

### HOW A ROW EARNS ITS MARK

- **REST / oBIX rows**
  the slot read-back after the write, not the write's own response.
- **Outside rows**
  a protocol frame captured or decoded from a client that does not share the station's code: Modbus FC03/FC06, BACnet Who-Is and ReadProperty, snmpget.
- **Counter rows**
  two reads of the same counter, separated by a known interval.

A slot that reports success without producing the observation is not evidence, so it never turns a blank row into a check mark.