

ASSURANCE CONSTRUCTION & SERVICES C-4 SCAFFOLD INSPECTION CHECKLIST		DATE		INSPECTION DONE BY	
		OK	OH&S CODE	COMMENTS IF NOT CHECKED OFF	
TYPE OF SCAFFOLDING:			PART 23		
	BRACKET		SECT. 332		
	DOUBLE POLE		SECT. 333, TABLES 1-4		
	FREESTANDING/ROLLING		SECT. 334		
	HALF HORSE		SECT. 335, TABLES 5 & 6		
	LADDERJACK		SECT. 336		
	NEEDLE BEAM		SECT. 337		
	OUTRIGGER		SECT. 338		
	SINGLEPOLE		SECT. 339, TABLES 7 & 8		
	SUSPENDED		SECT. 341		
	SWINGSTAGE		SECT. 342		
SCAFFOLD SQUARE, STRAIGHT, AND PLUMB IN ALL DIRECTIONS					
ALL SCAFFOLD COMPONENTS PRESENT, TIGHT AND SECURE AND IN PLACE			PART 23 SECT. 321		
NO SCAFFOLD MEMBERS OR PLANKS OVER EXTENDED AND HAZARDOUS – OVERHANG BASE PLATES AND SCREW JACKS FIRMLY SUPPORTED ON ALL LEGS – MUDSILLS LEVELLING ADJUSTMENT SCREWS EXTENDED INTO FASTENER			PART 23 SECT. 329(4)		
TOWER TIED TO RIGID SUPPORT HORIZONTALLY					
FREE STANDING TOWER OR SINGLE POLE SCAFFOLD STEADIED WITH GUY PER PROVINCIAL REGULATIONS					
PLATFORM PLANKING: MAXIMUM SPAN PROVINCIAL REGULATIONS CLEATED ON UNDERSIDE AT EACH END WITH WOOD OR ANGLE IRON TIED DOWN SECURELY			PART 23 SECT. 329		
VERTICAL ACCESS LADDER SECURELY FASTENED IN PLACE USED ONLY FOR ACCESS			PART 23 SECT. 327		
TAG SYSTEM BEING USED			PART 23 SECT. 326		
GUARD RAILS: PERIMETER TOE BOARDS PROVINCIAL REGULATIONS PERIMETER HAND RAIL PROVINCIAL REGULATIONS PERIMETER MID-RAIL PROVINCIAL REGULATIONS			PART 22 SECT. 315		
FALL PROTECTION			PART 9		
SEPARATE ROPE OR HAND LINE IN PLACE AT ALL PLATFORMS TO RAISE AND LOWER TOOLS OR MATERIAL					
WARNING DEVICES/SIGNS PROVIDED IF ERECTED OVER WALKWAYS OR ROADWAYS (FLASHING LIGHTS, REFLECTIVE TAPE STREAMERS, OR AREA IN ROPED OFF)			PART 22 SECT. 318		
MINIMUM CLEARANCE FROM OVERHEAD POWER LINES MAINTAINED AS PER SCHEDULE ROLLING SCAFFOLD WHEEL BRAKES LOCKED AND OUTRIGGERS EXTENDED TO MAINTAIN MAXIMUM HEIGHT RATIO PER PROVINCIAL REGULATIONS			7 M		
SPECIAL REQUIREMENTS:					