



North Carolina State Laboratory of Public Health
Environmental Sciences
Inorganic Chemistry
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-3937
Fax: 919-715-8610

Report To: RONNIE WHISNANT

Name of System:

GASTON CO ENVIRONMENTAL HEALTH

ALVIN JOHNSON

991 WEST HUDSON BLVD

208 CREST LN.

GASTONIA, NC 28052

Courier # 06-34-01

BELMONT, NC 28012

EIN: 566000300EH

StarLiMS ID: ES013013-0131001

Date Collected: 01/28/13

Time Collected: 12:59 PM

Date Received: 01/30/13

Collected By: Ronald Whisnant

Sample Type:

Sampling Point: Sample head

Well Permit #: 10101

Sample Source: New Well

Temp. at Receipt: 3.5

GPS #:

Sample Description:

Comment:

Nitrate_Nitrite (Profile)

Analyte	Result	Allowable Limit	Unit	Qualifier(s)
Nitrate	3.70	10.00	mg/L	
Nitrite	< 0.10	1.00	mg/L	

Report Date: 02/12/2013

Reported By: Arnold Hall