FICTIONAL - FOR SOFTWARE DEMONSTRATION ONLY - NOT FOR PLANT USE

MCC-1A1 480 V BUCKET DETAIL



BUCKET SCHEDULE: 1A1-03 MOV-E11-F004A RHR SUCTION VALVE, SIZE 1 STARTER. 1A1-07 FN-1A ROOM COOLER FAN, 20 HP, SIZE 2 STARTER.

NOTE: Incoming supply from load center transformer T-1A5 on SAMPLE-E-001.

TITLE	MCC-1A1 480 V Bucket Detail
SYSTEM	480 V Class 1E Distribution
SITE / UNIT	SAMPLE SITE (FICTIONAL) / Unit 1
DRAWN BY	R. Sample
DATE	2026-03-09

DWG NO.	REV
SAMPLE-E-002	A