



JADEC Mensor Digital Pressure Gauge Verification

Date: 12/7/2021
 Block: AHU
 Sensor: Ashcroft Differential Pressure Transmitter
 DP Sensor S/N: I14350108

Standard Model: Mensor 0-40 psig
 Std S/N: 830701
 Std Transmitter Model: Mensor CP6050
 Std Transmitter S/N: 41000PJ1

Standard Cal Due Date: 12/7/2022

DAQ Console and Channel Calibration Station 2 - No Channel Applies

DAQ Console and Channel Calibration Station 2 - Channel 1

Sensor Verification Data											
Nominal psia Target	Start Time			Sensor			Standard			Std - Sensor Diff in PSI	% Error
				Measured inH2O			Reading				
-15	12/7/2021 14:30:44			-14.971			-15.0000			-0.0295	0.1967%
-7.5	12/7/2021 14:37:44			-7.489			-7.5000			-0.0113	0.1507%
0	12/7/2021 14:44:44			-0.008			0.0000			0.0078	0.0000%
7.5	12/7/2021 14:51:44			7.506			7.5000			-0.0057	0.0760%
15	12/7/2021 14:58:44			15.043			15.0300			-0.013	0.0865%

Based on the above data, the listed DP sensor **PASSED** calibration verification.

Data Collected by: Daniel Mack

Reviewed and Approved: _____