



Johnson Controls Calibration Report

Unit Type: 570 Ton

Test Request Number: TR24-0043

Instrument Map Date: 9/3/2024 2:51:40

JADEC Test Facility: WC1200 Federal

Serial Number	Instrument Title	HW Tag Name	Calibration Dates		
			Next	Last	Status
ED17BB	COND WATER ENTERING TEMP A	DAQ2_RTD_001	2024-01-03	2024-07-03	Expired
ED1842	COND WATER ENTERING TEMP B	DAQ2_RTD_002	2024-01-03	2024-07-03	Expired
ED1A25	COND WATER LEAVING TEMP A	DAQ2_RTD_003	2024-01-03	2024-07-03	Expired
ED5421	COND WATER LEAVING TEMP B	DAQ2_RTD_004	2024-01-03	2024-07-03	Expired
ED53E6	EVAP WATER ENTERING TEMP A	DAQ2_RTD_005	2024-01-03	2024-07-03	Expired
ED1813	EVAP WATER ENTERING TEMP B	DAQ2_RTD_006	2024-01-03	2024-07-03	Expired
EDB86E	EVAP WATER LEAVING TEMP A	DAQ2_RTD_007	2024-01-03	2024-07-03	Expired
ED1834	EVAP WATER LEAVING TEMP B	DAQ2_RTD_008	2024-01-03	2024-07-03	Expired
DB0912	AUX COOLING WATER ENTERING TEMP	DAQ2_RTD_009	2024-01-03	2024-07-03	Expired
ED19D9	AUX COOLING WATER LEAVING TEMP	DAQ2_RTD_010	2024-01-03	2024-07-03	Expired
D7D36D	COMPRESSOR SUCTION TEMP SYS01	DAQ3A_RTD_001	2024-01-03	2024-07-03	Expired
D2DDC5	COMPRESSOR DISCHARGE TEMP SYS01	DAQ3A_RTD_002	2024-01-03	2024-07-03	Expired
D2DDCC	COMPRESSOR SUCTION TEMP SYS02	DAQ3A_RTD_003	2024-01-03	2024-07-03	Expired
D302E0	COMPRESSOR DISCHARGE TEMP SYS02	DAQ3A_RTD_004	2024-01-03	2024-07-03	Expired
D302D8	OIL COOLER WATER ON SYS01	DAQ3A_RTD_005	2024-01-03	2024-07-03	Expired
D2FCBD	OIL COOLER WATER OFF SYS01	DAQ3A_RTD_006	2024-01-03	2024-07-03	Expired
D31867	OIL COOLER WATER ON SYS02	DAQ3A_RTD_007	2024-01-03	2024-07-03	Expired
D31868	OIL COOLER WATER OFF SYS02	DAQ3A_RTD_008	2024-01-03	2024-07-03	Expired
D30438	EVAP LIQUID LOW CENTER RTD	DAQ3A_RTD_009	2024-01-03	2024-07-03	Expired
D31872	LIQUID OUT OF COND SYS01	DAQ3A_RTD_010	2024-01-03	2024-07-03	Expired
D3185C	LIQUID OUT OF COND SYS02	DAQ3A_RTD_011	2024-01-03	2024-07-03	Expired
D2F7AE	AMBIENT TEMPERATURE	DAQ3A_RTD_012	2024-01-03	2024-07-03	Expired
D30A7C	COND WATER LEAVING TEMP 01	DAQ3A_RTD_013	2024-01-03	2024-07-03	Expired
D30A76	COND WATER LEAVING TEMP 02	DAQ3A_RTD_014	2024-01-03	2024-07-03	Expired
460445	EVAP PRESSURE	DAQ3A_AI_001	2024-04-24	2024-10-24	60-Days
532127	COND PRESSURE	DAQ3A_AI_002	2024-04-24	2024-10-24	60-Days
460437	OIL PRESSURE SYS01	DAQ3A_AI_003	2024-04-24	2024-10-24	60-Days
532132	OIL PRESSURE SYS02	DAQ3A_AI_004	2024-04-24	2024-10-24	60-Days
460450	OIL SUMP PRESSURE	DAQ3A_AI_005	2024-04-24	2024-10-24	60-Days
490587	BAROMETRIC PRESSURE	DAQ3A_AI_006	2024-04-24	2024-10-24	60-Days
532126	CWCV INLET PRESSURE	DAQ3A_AI_007	2024-04-24	2024-10-24	60-Days
481316	CWCV OUTLET PRESSURE	DAQ3A_AI_008	2024-04-24	2024-10-24	60-Days
533524	CWCV BYPASS LEG PRESSURE	DAQ3A_AI_009	2024-04-24	2024-10-24	60-Days
1769839	EVAP WATER PRESSURE DROP	DAQ3A_AI_010	2024-04-24	2024-10-24	60-Days
1396531	COND WATER PRESSURE DROP	DAQ3A_AI_011	2024-04-24	2024-10-24	60-Days
1895448	OIL COOLER WATER PRESSURE DROP SYS01	DAQ3A_AI_012	2024-04-24	2024-10-24	60-Days
1042654	OIL COOLER WATER PRESSURE DROP SYS02	DAQ3A_AI_013	2024-04-24	2024-10-24	60-Days
14653233_14653224	EVAPORATOR WATER FLOW A	EVAP_WTR_E_FLOW_FT-EW-1A	2024-02-29	2026-02-28	OK
14653355_14653320	EVAPORATOR WATER FLOW B	EVAP_WTR_E_FLOW_FT-EW-1B	2024-02-29	2026-02-28	OK
14653234_14653225	CONDENSER WATER FLOW A	COND_WTR_E_FLOW_FT-CW-1A	2024-02-27	2026-02-27	OK
14731924_14731857	CONDENSER WATER FLOW B	COND_WTR_E_FLOW_FT-CW-1B	2024-02-27	2026-02-27	OK
12213539_26209955	OIL COOLER WATER FLOW SYS01	DAQ3A_AI_014	2022-06-15	2025-06-15	OK
12112441_25693743	OIL COOLER WATER FLOW SYS02	DAQ3A_AI_015	2023-08-09	2026-08-09	OK
0870135755_0860223583	CWCV BYPASS FLOW	DAQ3A_AI_016	2023-02-14	2025-02-14	OK
2643AD1606009	MOTOR 1 INPUT	XT2640-045	2024-02-21	2025-02-21	OK
2643AD2103004	MOTOR 2 INPUT	XT2640-066	2024-03-01	2025-03-01	OK

Prepared By: jbeachsc

Date: 9/3/2024