SAMPLE DOCUMENT: the project details are made up to show the format.

APEXON
GLOBAL TECHNOLOGIES

Handover Checklist

Client: Example Client Ltd (fictional)
Site: Example Office, Floor 2, Nairobi (fictional)
Checklist no.: SAMPLE-HC-001
Handover date: 01/01/2026

Installation

Item	Checked	Notes
All outlets installed in the agreed positions	☑	
Cables run in containment, neatly dressed and secured	☑	
Rack tidy, cable management fitted, doors and locks working	☑	
Ceilings, walls and floors made good after work	☑	
Site cleaned and waste removed	☑	

Testing and records

Item	Checked	Notes
Every link tested; test report issued (SAMPLE-TR-001)	☑	
Every cable, port and outlet labelled to the scheme (SAMPLE-LS-001)	☑	
As-built drawings issued (SAMPLE-AB-F2-001)	☑	
Equipment list, configuration and access details handed over	☑	

Walkthrough

Item	Checked	Notes
Client shown the rack, labelling and how to trace a cable	☑	
Client shown how to report a fault	☑	
Open items agreed with a date (if any)	☐	None

For Apexon Global Technologies: name, signature, date

For the client: name, signature, date

SAMPLE