

MAINTENANCE WORK ORDER

Greenleaf Residential LLC · (614) 555-0182 · maintenance@greenleafresidential.com

Work Order No.:	WO-2025-0391
Date Submitted:	December 2, 2025
Priority:	HIGH — water damage risk
Status:	Open — Awaiting Scheduling
Property / Unit:	Westview Four-Plex — Unit 1, 4812 Westview Drive, Columbus OH 43235
Tenant:	Denise Okafor
Tenant Phone:	(614) 555-2299

Problem Description

Tenant reports a slow leak under the kitchen sink. Water has been dripping from the P-trap connection for approximately 3 days. There is visible water staining on the cabinet floor. No mold observed yet. Tenant has placed a bucket under the drain as a temporary measure.

Scope of Work

1. Inspect P-trap and supply lines under kitchen sink.
2. Replace P-trap assembly and compression fittings as needed.
3. Check supply shut-off valves — replace if corroded.
4. Inspect cabinet floor for water damage; treat if early-stage.
5. Document with photos before and after repair.

Assigned Vendor

Vendor: Apex Plumbing & Mechanical LLC

Contact: Daniel K. Osei · (614) 555-0317

Scheduled: December 4, 2025 — 9:00 AM – 12:00 PM

Est. Cost: \$180 – \$240 (parts + 1.5 hrs labor)

Manager Approval: _____ **Date:** _____

Technician Sign-off: _____ **Completed:** _____