

Cascade Facilities

Assigned to **Callie Tanaka**

Asset

AHU-14

Priority **High**

Due date **July 5, 2026**

Checklist (checked = complete):

- ☒ Replace worn belt
- ☒ Check alignment
- ☐ Update service tag
- ☐ Clear intake screen
- ☐ Isolate power at panel
- ☐ Verify guard reinstalled

Technician notes: parts on hand, no downtime expected.