

SEVERN-TRENT WATER AUTHORITY

Water Act, 1973

Rivers (Prevention of Pollution) Acts, 1951-61

NOTIFICATION OF CONSENT

for Effluent Outlet and/or Discharge of Effluent to a Stream

Reference : 90/7/1449

EC/7/1/5

Consent No. : WQ/7/2186

To : Severn Trent Water Authority
Registered
Lords

SOV-983-51-28

THE SEVERN-TRENT WATER AUTHORITY in pursuance of the powers conferred on them by the above-mentioned Acts HEREBY CONSENT to your

bringing into use new outlet(s) for the discharge of effluent to a stream

beginning to make new discharge(s) of effluent to a stream

~~continuing to make~~ discharge(s) of effluent to a stream

as described below, the subject of your application dated 1 June 1983

SUBJECT to the conditions attached.

Description of outlet(s)

1. The river is the River Trent, which flows through the town of Loughborough, Leicestershire, and discharges into the Trent River at Loughborough.

2. The effluent is the effluent from the sewage treatment works at Loughborough, Leicestershire, which is discharged into the Trent River at Loughborough.

Description of effluent(s)

1. The effluent consists of the effluent from the sewage treatment works at Loughborough, Leicestershire, which is discharged into the Trent River at Loughborough.

Dated this 1st day of June 1983

ABELSON HOUSE,
2297 COVENTRY ROAD,
SHELDON,
BIRMINGHAM.

Director of Scientific Services

10/7/2188

The outlet shall be located as shown marked "SURFACE WATER OUTLET" on Drawing No WQ/7/2188/1

- 2 The outlet shall be constructed in accordance with Drawing No WQ/7/2188/2 (submitted Drawing No PG20:188)
- 3 The outlet shall be used only for the discharge of sewage effluent as described herein.
- 1 The effluent discharged to the stream shall consist only of foul sewage from the sewage pumping station situated at Cornwood Meadows Industrial Development, Cromford Road, Langley Hill, Derbyshire or surface water from the sewerage system draining the development or a mixture thereof
- 2 The discharge of effluent passing to the stream from the sewage pumping station shall be limited to an overflow from the sump when the pumping station ceases to operate due to circumstances outside the control of the Authority and it is not reasonably practicable to dispose of the sewage otherwise.

Assistant Director of Scientific Services
16 November 1983

The terms of this Consent will not, without the consent in writing of the person to whom this Consent is given (or his successor), be altered before the expiration of the period ending with the eighteenth day of November 1985.