

SECTION 26 0583 - ADDITIONAL ELECTRICAL EQUIPMENT – ATTIC STOCK

PART 1 - GENERAL

1.1 Provide unit pricing in Base Bid to furnish and install the following items:

- A. The purpose of these items is to allow for adjustments of Electrical Systems of a minor nature during course of work.
- B. Unused items will be turned over to the Owner with a credit for labor as reflected in the unit prices.
 - 1. Five (5) fire alarm chime light units and 20 foot of conduit and wire to connect to an adjoining device.
 - 2. Four (4) fire alarm duct detectors and 20 foot of conduit and wire to connect to an adjoining device.
 - 3. Two (2) fire alarm control zams with 20 foot of conduit and wire to connect to adjacent device.
 - 4. Two (2) fire alarm strobe lights with 20 foot of conduit and wire to connect to adjacent device.
 - 5. Two (2) fire alarm manual pull stations and 20 foot of conduit and wire to connect to adjoining device.
 - 6. Two (2) 0 to 100 amp 3-pole breakers installed in CCB type panel.
 - 7. Five (5) duplex outlets with plated in outlet box with 20 foot of conduit and wire to connect to adjacent circuit.
 - 8. Five (5) single pole switch with plates in outlet box with 20 foot on conduit and wire to connect to adjacent device.

PART 2 - PRODUCTS

- A. See individual sections for item requirements.

PART 3 - EXECUTION

- A. Include all items in Base Bid.
- B. Provide a list of unit prices for each item which consist of materials, labor, and equipment required for a complete installation.
- C. Include programming for fire alarm devices.
- D. Attic Stock items to be delivered to Owner in original, unopened package(s), to be stored at a location of Owner's discretion, with all items clearly identified on the exterior of the package(s).

END OF SECTION

