

CERTIFICATE OF ANALYSIS

CERTIFICATE NO.: B767408 Page 1 of 3
ISSUE DATE: 1/04/19

REVISION NO: 00
 This certificate supersedes any previous revisions

CLIENT DETAILS:

DATE RECEIVED: 20/03/2019
CLIENT REF. NO:
ORDER NO: 9724

JOB INFORMATION: Water
RECEIVE CONDITION: 5.0 °C
STORAGE CONDITION: 4 °C
TEST DATE: Sample tested between date received and reported

RESULTS OF ANALYSIS:

Test	Method Code	LOR	Unit	B767408-1 1. GC Tap Water	B767408-2 2. RO Water	B767408-3 3. H1-24	B767408-4 4. H1-27
FSA001 Water							
Fluoride	EFF015	0.05	mg/L	0.74	<0.05	<0.05	<0.05
Chloride	EFF011	2	mg/L	25	3.0	4.1	4.2
Electrical Conductivity	EFF007	5	µS/cm	230	18	50	140
NOx (as N)	EFF004.1	0.005	mg/L	0.036	0.012	0.0090	0.017
pH	EFF006		pH Unit	7.46	6.83	9.43	10.61
Iron (Total)	EWI02	0.01	mg/L	0.020	<0.01	<0.01	<0.01
Manganese (Total)	EWI02	0.01	mg/L	<0.010	<0.010	<0.010	<0.010
Hardness (Total)#	EFF025	1	mg/L	52	1	14	13
Sulphate	EFF016	5	mg/L	14	<5.0	<5.0	<5.0
Reactive Silica	ENV007	0.1	mg/L	9.1	0.42	0.57	0.59
Carbon Dioxide (Free)#	EFF034	0.2	mg/L	3.0	0.9	<0.2	<0.2
Solids (Dissolved)	EFF010	2	mg/L	220	5.0	26	55
Saturation Index#	EFF087		-	-1.12	-4.61	0.06	-0.19



The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.
 Accredited for compliance with ISO/IEC 17025 – Testing.
 NATA Corporate Accreditation No.: 2455

Symbio Laboratories Pty Ltd
 ABN 82 079 645 015

▪ Tel: 1300 703 166 ▪ Fax: +61 7 3219 0333
 This document must not be reproduced except in full.

- Brisbane: 52 Brandl Street, Eight Mile Plains QLD 4113
- Townsville: 17 Hamill Street, Garbutt QLD 4814
- Melbourne: Unit 36, 640-680 Geelong Rd, Brooklyn VIC 3025
- Sydney: 2 Sirius Rd, Lane Cove West NSW 2066
- Wagga Wagga: Unit 5, 10-12 Koorringal Rd, Wagga Wagga NSW 2650
- Perth: 2/20 Milford Street, East Victoria Park WA 6101

Test	Method Code	LOR	Unit	B767408-1 1. GC Tap Water	B767408-2 2. RO Water	B767408-3 3. H1-24	B767408-4 4. H1-27
SAR (Sodium Adsorption Ratio)#	EFF063	0.8		1.3	-	<0.8	<0.8
Alkalinity Total (CaCO ₃)	EFF031	1	mg/L	44	3	16	34
Alkalinity Bicarb (CaCO ₃)	EFF031	1	mg/L	44	3	3	<1
Alkalinity Carbonate (CaCO ₃)	EFF031	1	mg/L	<1	<1	14	14
Alkalinity Hydroxide (CaCO ₃)	EFF031	1	mg/L	<1	<1	<1	20
Magnesium (Total)	EWI02	0.05	mg/L	4.2	0.070	0.23	3.1
Calcium (Total)	EWI02	0.1	mg/L	14	0.23	5.2	0.1
Sodium (Total)	EWI02	1	mg/L	21	2.3	2.5	3.5
Silver (Total)	EWI02	0.01	mg/L	0.010	<0.010	<0.010	<0.010
Arsenic (Total)	EWI02	0.05	mg/L	<0.05	<0.05	<0.05	<0.05
Boron (Total)	EWI02	0.05	mg/L	<0.05	<0.05	<0.05	<0.05
Barium (Total)	EWI02	0.01	mg/L	0.01	<0.01	<0.01	<0.01
Beryllium (Total)	EWI02	0.01	mg/L	<0.010	<0.010	<0.010	<0.010
Cadmium (Total)	EWI02	0.01	mg/L	<0.010	<0.010	<0.010	<0.010
Cobalt (Total)	EWI02	0.01	mg/L	<0.010	<0.010	<0.010	<0.010
Chromium (Total)	EWI02	0.01	mg/L	<0.010	<0.010	<0.010	<0.010
Copper (Total)	EWI02	0.01	mg/L	0.090	<0.01	<0.01	<0.01
Potassium (Total)	EWI02	0.2	mg/L	1.8	<0.2	0.68	20
Molybdenum (Total)	EWI02	0.01	mg/L	<0.010	<0.010	<0.010	<0.010
Nickel (Total)	EWI02	0.01	mg/L	<0.01	<0.01	<0.01	<0.01
Lead (Total)	EWI02	0.02	mg/L	<0.02	<0.02	<0.02	<0.02
Antimony (Total)	EWI02	0.02	mg/L	<0.02	<0.02	<0.02	<0.02
Selenium (Total)	EWI02	0.05	mg/L	<0.05	<0.05	<0.05	<0.05
Acid Soluble Silicon	EWI02	0.1	mg/L	4.25	0.36	0.51	0.81
Strontium (Total)	EWI02	0.01	mg/L	0.060	<0.010	0.020	<0.010
Vanadium (Total)	EWI02	0.02	mg/L	<0.020	<0.020	<0.020	<0.020
Zinc (Total)	EWI02	0.02	mg/L	<0.02	<0.02	<0.02	<0.02
General Tests							
Chlorine (Free)	EFF027	0.01	mg/L	0.52	0.02	0.02	0.02
Chlorine (Total)	EFF028	0.01	mg/L	0.66	0.03	0.02	0.03



The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.
Accredited for compliance with ISO/IEC 17025 – Testing.
NATA Corporate Accreditation No.: 2455

Symbio Laboratories Pty Ltd

ABN 82 079 645 015

Tel: 1300 703 166

Fax: +61 7 3219 0333

This document must not be reproduced except in full.

- Brisbane: 52 Brandl Street, Eight Mile Plains QLD 4113
- Townsville: 17 Hamill Street, Garbutt QLD 4814
- Melbourne: Unit 36, 640-680 Geelong Rd, Brooklyn VIC 3025
- Sydney: 2 Sirius Rd, Lane Cove West NSW 2066
- Wagga Wagga: Unit 5, 10-12 Koorringal Rd, Wagga Wagga NSW 2650
- Perth: 2/20 Milford Street, East Victoria Park WA 6101

DEFINITIONS: < : Less than, > : Greater than, [NT] : Not Tested, DWB : Dry Weight Basis, NA: not applicable, RP: Result Pending, - : Not received / requested / tested, ~ : Estimated, TBA: - to be advised, Δ: reference only holding time exceeded

* Test not covered by NATA scope of accreditation

: The result is derived from a calculation and includes results equal to, or greater than the LOR. Where applicable, results are calculated as sum of reportable isomers.

Results were reported on an "as received" basis unless otherwise indicated.

Sampling was conducted by the customer and results reported pertain only to the samples submitted.

Responsibility for representative sampling rests with the customer.



Hoyun Jeong, Team Leader
Chemistry (Brisbane)



The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.
Accredited for compliance with ISO/IEC 17025 – Testing.
NATA Corporate Accreditation No.: 2455

Symbio Laboratories Pty Ltd
ABN 82 079 645 015

▪ Tel: 1300 703 166 ▪ Fax: +61 7 3219 0333
This document must not be reproduced except in full.

- Brisbane: 52 Brandl Street, Eight Mile Plains QLD 4113
- Townsville: 17 Hamill Street, Garbutt QLD 4814
- Melbourne: Unit 36, 640-680 Geelong Rd, Brooklyn VIC 3025
- Sydney: 2 Sirius Rd, Lane Cove West NSW 2066
- Wagga Wagga: Unit 5, 10-12 Koorringal Rd, Wagga Wagga NSW 2650
- Perth: 2/20 Milford Street, East Victoria Park WA 6101