



PIPE CUT LENGTH SUMMARY					
SPL No.	NPD	PC No.	LENGTH	ALLOWANCE	TOTAL LENGTH
S17_SBF	0.75	<10>	0.227	0.000	0.227
S17_SBF	0.75	<11>	0.146	0.000	0.146
S18_SBF	0.75	<12>	0.610	0.000	0.610
S18_SBF	0.75	<13>	0.668	0.000	0.668

SXX_Spool Sequence Number (S03.02)
 SXX_SP - Fab - Spool
 SXX_SP_Fab - P to P Doubling - 46M+5M
 SXX_ERec - Random Pipe (6M.12M)
 SXX_ERec - Part Loose Fittings
 SXX_ERec - Range (EF-Loose Range, EF-Bldg, EF-Spectacle)
 SXX_Inv - Erec. valve
 SXX_Pipe - Erec. Pipe Plug
 SXX_SBF - Small Bore Spool Fab.
 SXX_SBF - Small Bore Spool Erec.
 SXX_SBF - Small Bore Spool Dren
 SXX_SBF - Small Bore Spool Vent

X	PART NUMBER
<X>	PIECE NUMBER
(S-X)	SHOP WELD
(F-X)	FIELD WELD
(SXX_ID)	SPOOL NUMBER

ISO For

NOTES :

1. ALL COORDINATES AND ELEVATIONS ARE IN 'METER' AND ALL DIMENSIONS ARE IN 'MM'.
2. PIPE QUANTITY IS IN METERS AND OTHER QUANTITY IN NUMBERS.
3. FOR STANDARD SUPPORT, REFER DOC. NO. "PP-866-ST-0001".
4. IN CASE OF ANY DISCREPANCY FOR LINE CONDITIONS, LINE DATA GIVEN IN LINE LIST SHALL GOVERN
5. FOR SMALL BORE LINES, DIMENSION & ROUTING SHALL BE FIELD ADJUSTED.
6. THE SPECIFIED THEORETICAL LOCATION OF EQUIPMENT NOZZLES, SUPPORTING STRUCTURE SHALL BE VERIFIED BEFORE INSTALLING THE PIPING & INTOLERABLE DISCREPANCIES SHALL BE DISCUSSED WITH DESIGN SITE ENGINEER.
7. ALL THREADED CONNECTION SHALL BE SEAL WELDED, EXCEPT DRAIN AND VENT PLUG.
8. REFER LINE LIST.
9. ALL PRESSURE WELDS, OTHER THAN BUTT WELDS, INCLUDING BRANCH CONNECTIONS SUCH AS BRANCH-OLETS, AND BOSS) SHALL BE 100% PT/MT EXAMINED. ALL ATTACHMENT WELDS ON PRESSURIZED COMPONENTS THAT ARE NOT HYDROTESTED AFTER MAKING THE ATTACHMENT

BUTT WELD  INSULATED PIPE  PIPE SUPPORT  SOCKET WELD 	FIELD WELD  TRACED PIPE  PLATFORM PATTERN  SCREWED JOINT 
--	--

THIS DRAWING AND THE INFORMATION CONTAINED HEREIN ARE THE SOLE PROPERTY OF SAUDI ARAMCO. NO REPRODUCTION IN FULL, OR IN PART, SHALL BE OBTAINED FROM THIS DRAWING WITHOUT THE WRITTEN CONSENT OF SAUDI ARAMCO.