

Plant HOT RO DISTRUBUTION	Client PURAC	Code	Document ID Code	Project No. MOC E123/25
	INSTRUMENT DATA SHEET ON/OFF VALVE			 Corbion Page 1 of 4

Improvement of biopurge pipe from 540-VA-495 to WWT

Cover Sheet

0	IFQ	Issued for Inquiry	23.01.26	KP	23.01.26	WT	23.01.26	TS	
Rev.	Status	Description	Date	Prepared	Date	Checked	Date	Approved	AC

Plant HOT RO DISTRUBUTION	Client PURAC	Code	Document ID Code	Project No. MOC E123/25
	INSTRUMENT DATA SHEET ON/OFF VALVE			 Corbion
		REV	0	Page 2 of 4

Content	Page
1 Cover Sheet	1
2 Content	2
3 List of Data sheet	3
4 Data Sheet	4

[illegible]

GENERAL	1	Tag No.	P&ID No.	540-XV-478	510 SH.113
	2	Service			Hot Water to Mixed Condensate
	3	Application	Hazardous area	Close/Open	Zone 2
	4	Line No.	Insulation	560-2"-WH10-XXX	
	5	Line Size	I.D. (mm.)	2"	52.48
	6	Fluid Code			WH10
PROCESS DATA	7	Fluid	Phase	Water HL condensate	Liquid
	8	Design Press (Barg)	Oper. Pressure (Barg)	FV / 10	6.00
	9	Design Temp (°C)	Oper. Temp (°C)	10 / 120	80
	10	Max allowable shut off pressure			10
VALVE BODY	11	Manufacturer			VTA
	12	Valve Model			VTA
	13	Design			MFR Std., Full Bore
	14	Body Size	Body Form	2"	Ball valve
	15	Body Material			SS316L
	16	Connection Size	Rating	2"	ANSI 150
	17	Flange Finished	Bolting	Flanged RF	MFR Std.
	18	Packing	Lubrication & Isolation	S.S. 1.4401	===
	19	Trim Material			SS316L
	20	Seat Material			PTFE
	21	Valve Cv	Leakage Class	Mfr.Std	Class V
	22	Fire safe requirement	Valve Class	===	#150
ACTUATOR	23	Manufacturer			VTA
	24	Model No.			VTA
	25	Type	Size	Pneu. Single-acting w/spring return	VTA
	26	Bonnet Type			Mfr.Std
	27	Actuator Orientation	Travelling Direction	Mfr.Std	Mfr.Std
	28	Ingress Protection	Electrical Protection	IP 65	Zone 2
	29	Stem Material			MFR Std.
	30	Action On Air Fail.	Action On Power Fail.	FC	FC
	31	Fire Protection			===
	32	Speed Of Operation	: Design	MFR Std.	
	33	(sec.)	: Actual	MFR Std.	
	34	Control Schematic Dwg. No.	Rev.	MFR Std.	===
ACCESSORIES	35	Limit Switch Closed	Tag. no.	PNP (NO) contact	540-ZSC-478
	36	Limit Switch Open	Tag. no.	PNP (NO) contact	540-ZSO-478
	37	Position Controller	Tag. no.	===	===
	38	Speed Controller			===
	39	Hand Wheel	Mounting Position	===	===
	40	Travel Stopper Position			===
	41	Air Filter/ Regulator			Norgren
	42	Safety Valve	Tag. no.	===	===
	43	Pressure Gauge	Tag. no.	Yes	===
	44	Pressure Switch	Tag. no.	===	===
	45	Solenoid Valve	Tag. no.	IMI-Norgren	540-XY-478
	46	Reset Lever			===
	47	When SOV Energized - Pressure To :			Open
OPTIONS	48	Material Cert.	Hydro. Cert.	Leakage Cert.	Yes Yes Yes
	49	Cleaning	PWHT Certificated Req		
	50	Factory Function Test Cert. Required			Yes
	51	NACE Certification Required			===
PURCHASE	52	P.O. Number			===
	53	Price	Item Number	===	1

Notes:

Prepared by:	KP	Checked by:	WT	Approved by:	TS	Date:	23.01.26
				INSTRUMENT SPECIFICATION On-Off Valve			
0	KP	23.01.26	Issued for inquiry			Sheet 1	of 1
Rev.	By	Date	Description	Doc.ID. 10853-DS-540-XV-478			