



IMDG - UN card

UN 1044

UN number 1044		Shipping name FIRE EXTINGUISHERS ILD SLUKKERE				
Class 2.2	Packing group —	Hazard labels 2.2	Marine pollutant Maybe	EmS F-C, S-V	<i>ADR transport category: 3 ADR tunnel: (E)</i>	
Hazard labels 		Marking UN 1044 FIRE EXTINGUISHERS				
Packaging Can be packed in suitable packaging according to packing instruction P003. Note: Large fire extinguishers may also be carried unpackaged provided that the requirements of 4.1.3.8.1 (a) to (e) are met, the valves are protected by one of the methods in accordance with 4.1.6.8 (a) to (d) and other equipment mounted on the fire extinguisher is protected to prevent accidental activation. For the purpose of this special packing provision, "large fire extinguishers" means fire extinguishers as described in indents (c) to (e) of special provision 225 of Chapter 3.3 (PP91).						
Mixed packaging The substance may be packaged with other substances in the same outer packaging if: - it is permitted to load the substances together, and - the substances do not react dangerously with one another.						
Remarks Fire extinguishers under this entry may include installed actuating cartridges (cartridges, power device of division 1.4C or 1.4S) without changing the classification of class 2.2 provided the total quantity of deflagrating (propellant) explosives does not exceed 3.2 g per extinguishing unit. Fire extinguishers shall be manufactured, tested, approved and labelled according to the provisions applied in the country of manufacture. Note: "Provisions applied in the country of manufacture" means the provisions applicable in the country of manufacture or those applicable in the country of use. Fire extinguishers under this entry include: 1. portable fire extinguishers for manual handling and operation; 2. fire extinguishers for installation in aircraft; 3. fire extinguishers mounted on wheels for manual handling; 4. fire extinguishing equipment or machinery mounted on wheels or wheeled platforms or units transported similar to (small) trailers; and 5. fire extinguishers composed of a non-rollable pressure drum and equipment, and handled, e.g. by fork lift or crane when loaded or unloaded. Note: Pressure receptacles which contain gases for use in the above-mentioned extinguishers or for use in stationary fire-fighting installations shall meet the requirements in chapter 6.2 and all requirements applicable to the relevant dangerous goods when these pressure receptacles are transported separately (SP 225).						
Properties and observations Fire extinguishers, containing compressed or liquefied gases under pressure above 175 kPa for expelling fire-extinguishing contents.						
Tank type:	Not allowed	Transport in bulk		Orange panel		
Tank provisions:	—	Not allowed		1044		
Stowage and segregation						
Stowage There are no special requirements for stowage.						
Segregation Check the segregation table for sea transport. There are no special requirements for segregation.						
Placarding of the transport unit Containers, semi-trailers and tank containers must be marked with enlarged hazard labels (placards) on all four sides. Railway wagons must at least be marked with placards on both sides. All other transport units, e.g. trucks etc., must at least be placarded on both sides and at the back. The placards must have a size of at least 250 x 250 mm, and be of such quality that the labeling is still visible after 3 months at sea.						
Foodstuff The substance is not required to be kept separate from food and feed.						
Limited quantities (LQ) <i>Combination packaging</i> Inner: 120 mL Outer: 30 kg <i>Trays</i> Inner: 120 mL Outer: 20 kg		Parcel label: 		Excepted quantities (EQ) <i>Combination packaging</i> Inner: Not allowed Outer:		