



Example Hotel

Example Site / Example Location | Net Zero Discovery Roadmap

Second Discovery Assessment — Progress Review & Next Steps

Author: Jon Cullum | FAO: Example Contact | Date: DD/MM/YYYY | Previous: DD/MM/YYYY

Prepared by

Jon Cullum

FAO: Example Contact

Date

DD/MM/YYYY

Previous Assessment

15/01/2025

Year-on-Year Performance

▼ 12.3%

Gas Consumption (vs Year 1 baseline)

▼ 9.1%

Electricity Consumption (vs Year 1 baseline)

▼ 10.8%

Carbon Emissions CO₂ (vs Year 1 baseline)

Progress Since January 2024

Recommendation (Jan 2024)	Status	Notes	
LED Lighting – Guest Rooms & Corridors	✓ Complete	Completed Q2 2024 – estimated 18% electricity saving on lighting circuits.	
Pool Heat Pump Service	✓ Complete	Refrigerant topped up, COP improved from 2.8 to 3.6.	
Voltage Optimisation – Kitchen	✓ Complete	Installed on main kitchen circuit Q3 2024.	
Staff Energy Awareness Programme	In Progress	Energy champions appointed; monthly meetings ongoing.	
EnPact Filter Pro – Mains Incomer	Recommended	See Top 5 Priority Recommendations	⚠ Highest priority
Insulation Jackets – Boiler Plant	Recommended	Free T&M survey recommended as immediate next step.	
Limescale Inhibitors – AquaVantage	Recommended	Proposal ready – awaiting instruction.	
BMS Optimisation – HVAC Schedules	Recommended	Overnight base load analysis confirms priority.	

Top 5 Priority Recommendations

The following five measures represent the highest-impact opportunities currently available to Example Hotel.

#	Recommendation	Indicative Cost	Estimated Saving	Expected ROI	Saving Type	What It Does
1	EnPact Filter Pro	circa £10,000	10–15% electricity saving	Under 12 months	Electrical	Passive power conditioning at the mains incomer. Corrects power factor, filters harmonics and stabilises voltage. Includes real-time circuit-level energy monitoring.
2	Insulation Jackets — Boiler Plant	Free survey; cost TBC	circa 10% gas saving	Circa 12 months	Gas	Removable, zip-off insulation jackets over exposed pipework, valves and heat exchangers in the boiler plant room. Unfasten for maintenance, refit straight after.
3	Limescale Inhibitors — AquaVantage	circa £18,500	Reduced water heating & maintenance costs	Under 12 months	Electrical & Gas	Chemical-free electronic water conditioning across all 87 guest room circuits. Prevents new limescale on shower heads, pipework and heating surfaces.
4	Real-Time Energy Monitoring	Included with EnPact	Enables & verifies all other savings	Circa 12 months	Electrical	Circuit-level sensors on HVAC, mains incomer, kitchen, laundry and all plant rooms. Live dashboard identifies overnight base load and confirms savings.
5	Gas Saving Solutions on Boilers	At next boiler service	10–15% gas saving	Circa 12 months	Gas	EndoTherm heat-transfer additive and magnetic fuel conditioners. Best installed at next scheduled service with full system flush.

Your Net Zero Roadmap — Phased Action Plan

NOW — Quick Wins	NEXT 3 MONTHS	MEDIUM TERM
✓ EnPact Filter Pro — proceed with proposal ✓ Insulation jackets — book free T&M survey ✓ AquaVantage — proceed with proposal ✓ EndoTherm + fuel conditioners at next boiler service ✓ BMS reschedule — M3 Automation survey	• Emissis monitoring — install & commission • EnPact HVAC + Contine WM on AHUs • Smart thermostat pilot — guest room floor trial • Technik 2 on bar/restaurant fridges • Review EDF gas contract (renewal due)	• Solar PV feasibility — south-facing roof (80–100 kWp) • EV charging installation — car park feasibility • Rainwater harvesting — laundry and toilet circuits • Thermal imaging — flat roof and older window seals • Carbon reduction display at main reception

The Bottom Line

Together, the Top 5 recommendations target a further 10-15% reduction in both gas and electricity - on top of the 12.3% and 9.1% already achieved since the first assessment in January 2024. Combined estimated gas saving: 160,000-240,000 kWh annually. Combined electricity saving: 60,000-90,000 kWh annually.

To discuss any recommendation, request a free survey, or obtain a formal proposal, please contact Jon Cullum directly.