

9.0 MACHINERY TAG OUT PROGRAM

Purpose

This policy and procedure establish the minimum requirements for EAFab Corporation Machinery Tag Out Program. It governs lock out and/or tag out procedures to be used to verify that equipment or machines are isolated from all potentially hazardous energy.

Machinery is to be locked out or tagged out before employees perform any servicing or maintenance activities where the unexpected energizing, start up or release of stored energy could cause injury.

Policy

Procedures described apply to all electrical equipment and machinery connected to an energy source by either hard wire or other permanent connection (hydraulic lines, electrical, etc.) that is repaired, serviced, or maintained by EAFab Corporation personnel.

The Machinery Tag Out Program applies to all equipment or machinery operated by mechanical, hydraulic, pneumatic, chemical, thermal, or other energy resources where the unexpected energizing could cause injury to employees or customers.

Circuit breakers disconnect switches, and other energy isolating devices used to control the flow of energy to the machine/equipment must be operated in such a manner as to shut off or "isolate" all energy to the machine.

Definitions

Energy Source Any source of electrical, mechanical, hydraulic, chemical, thermal, or any other energy source.

Energized Connected to an energy source or containing residual or stored energy.

Device A mechanical device that physically prevents the transmission or release of energy (like, circuit breaker, disconnect switch, slide gate, line valve, etc.)

Lock out Placing a lock out device on an energy isolating device to shut down its flow of energy.

Lock out device A device such as a lock, either combination or key type, to hold an energy isolating device in the "safe" position and prevent energizing of a machine or equipment.

Tag out Placing a tag or sign on an energy isolating device indicating that the equipment shall not be operated until the tag out sign is removed.

Tag out device A prominent warning device or sign that can be attached to the energy isolating device. Tags will state the following: DANGER : DO NOT OPERATE