

FACILITY NAME Frankfurt DC-04 Hub	OPERATOR Nexus Cloud Infrastructure SE	LOCATION / COUNTRY Frankfurt am Main, DE	EU REGISTRY ID EED-DE-8839201
INSTALLED IT CAPACITY 12,500 kW (12.5 MW)	COMPUTER ROOM SPACE 4,200 m²	REDUNDANCY STANDARD 2N Electrical / N+1 Cooling	PRIMARY USAGE Colocation / Enterprise Cloud

1. CORE ENVIRONMENTAL INDICATORS (MANDATORY EED / ENefG KPIS)

POWER USAGE EFFECTIVENESS 1.24 PUE ✓ Meets EU Baseline (<1.30)	WATER USAGE EFFECTIVENESS 0.18 L/kWh ✓ Dry Cooling Optimized	ENERGY REUSE FACTOR 11.4 % ✓ District Heating Feed	RENEWABLE ENERGY SHARE 100 % ✓ PPA + Guarantees of Origin
---	---	--	---

2. ANNUAL ENERGY & ENVIRONMENTAL BALANCE SHEET (2025)

ENERGY & FLUID FLOW CATEGORY	ANNUAL QUANTITY	UNIT	MEASUREMENT SOURCE / METHODOLOGY
Total Facility Energy Input (\$E_{DC}\$)	72,450.00	MWh	Utility Main Grid Meter (ISO 50001 Verified)
IT Equipment Energy Consumption (\$E_{IT}\$ \$)	58,427.42	MWh	UPS Output / Sub-metering Network
Cooling System Energy Consumption	9,820.10	MWh	Chiller & Adiabatic Heat Exchanger Meters
Facility Auxiliaries & Lighting	4,202.48	MWh	Distribution Panel Telemetry
Waste Heat Exported to Off-Taker	8,259.30	MWh	Thermal Energy Meter (Local District Network)
Total Incoming Water Consumption	10,516.90	m³	Municipal Water Metering

Waste Heat & District Heating Integration Notice (EnEfG §17 Compliance)

During calendar year 2025, facility waste heat was supplied at a constant supply-temperature of 38°C to the adjacent municipal district heating scheme operated by MainKraft GmbH. Total thermal energy transferred was 8,259.30 MWh, exceeding the minimum 10% statutory waste heat utilization threshold set for facilities commissioned prior to 2026.

3. ICT CAPACITY & NETWORK DATA TRAFFIC SUMMARY

INDICATOR (DELEGATED REG EU 2024/1364)	TENANT AGGREGATED VALUE	REPORTING UNIT	DATA SOURCE / VERIFICATION STATUS
Total Installed Server Units	14,280	Physical Units	Annual Tenant Survey (100% Response Rate)

Indicator (Delegated Reg EU 2024/1364)	Tenant Aggregated Value	Reporting Unit	Data Source / Verification Status
Total Raw Storage Capacity	184.50	Petabytes (PB)	Colocation Tenant Disclosure Portal
Maximum Installed Network Bandwidth	800.00	Gbps	Edge Router Interconnect Capacity
Total Annual Ingress Data Traffic	1.12	Exabytes (EB)	Border Gateway Protocol (BGP) NetFlow Logs
Total Annual Egress Data Traffic	1.48	Exabytes (EB)	Border Gateway Protocol (BGP) NetFlow Logs

4. REGULATORY COMPLIANCE ATTESTATION

Regulatory Directive	Compliance Status	Regulatory Reference & Submissions
EU Energy Efficiency Directive (EED)	Fully Compliant	Reported under Delegated Regulation (EU) 2024/1364 into the European Database on Data Centres.
German Energy Efficiency Act (EnEfG)	Fully Compliant	Submitted to BfEE Data Centre Register (§13) & Platform for Waste Heat (§17) prior to March 31 deadline.
EU Taxonomy Alignment	Substantially Aligned	Complies with Do No Significant Harm (DNSH) and EU Code of Conduct for Energy Efficiency in Data Centres.

Data Center Managing Director:
Dr. Marcus Vance, VP Data Center Operations

Independent Environmental Auditor:
Elena Rostova, Lead Auditor (ISO 50001 / EMAS)

Nexus Cloud Infrastructure SE

TÜV Rheinland Energy & Environment GmbH