

TIME RANGE

Last 365 Days (2025 YTD)

FACILITY ID

EED-DE-8839201 (Frankfurt DC-04)

REGULATORY MANDATE

EED Reg 2024/1364 + EnEfG

DATA INGESTION INDEX

index=dc_telemetry_prod

POWER USAGE EFFECTIVENESS (PUE)

1.24

▼ -0.03 vs 2024 | Target: ≤ 1.30

WATER USAGE EFFECTIVENESS (WUE)

0.18 L/kWh

Optimal | Dry Adiabatic Active

ENERGY REUSE FACTOR (ERF)

11.4 %

8,259.3 MWh Heat Transferred

RENEWABLE ENERGY SHARE

100 %

PPA + Guarantees of Origin

ENERGY CONSUMPTION & HEAT BALANCE (MWH)

TELEMETRY SOURCE	MWH (YTD)	ISO / METER ID	STATUS
Facility Energy Input (\$E_{DC}\$)	72,450.00	GRID-MTR-01	VALIDATED
IT Equipment Load (\$E_{IT}\$)	58,427.42	UPS-OUT-AGG	VALIDATED
Cooling Plant Load	9,820.10	CHIL-MTR-01..04	ACTIVE
Auxiliaries & Lighting	4,202.48	PDU-AUX-MAIN	ACTIVE
Exported Waste Heat	8,259.30	HEAT-X-TOWN01	OFF-TAKING

UNDERLYING SPLUNK SEARCH (SPL)

index=dc_telemetry_prod facility_id="EED-DE-8839201"
| stats sum(kwh_val) as total_kwh by metric_type
| eval MWh=round(total_kwh/1000, 2) | table metric_type, MWh

EED ICT CAPACITY & NETWORK TELEMETRY SUMMARY

METRIC NAME	AGGREGATED VALUE	UNIT	COLLECTION PIPELINE
Active Physical Servers	14,280	Units	Colo Customer Portal API
Raw Provisioned Storage	184.50	PB	Tenant Asset Registry
Edge Router Interconnect	800.00	Gbps	SNMP Interface Poller
Annual Ingress Volume	1.12	EB	NetFlow / sFlow Aggregator
Annual Egress Volume	1.48	EB	NetFlow / sFlow Aggregator

UNDERLYING SPLUNK SEARCH (SPL)

index=dc_network_flow OR index=tenant_inventory
| stats count(server_id) as servers, sum(bytes_in) as total_in
| eval Ingress_EB=round(total_in/1e18, 2)

AUTOMATED EU REGULATORY SUBMISSION PIPELINE

TARGET FRAMEWORK	FILING AGENCY	AUTOMATED DEADLINE	DATA PAYLOAD STANDARD	EXPORT STATUS
German EnEfG §13 / §17	BfEE (Federal Energy Office)	March 31, 2026	Structured CSV / API Payload	EXPORT READY
EU EED Reg 2024/1364	European Database on Data Centres	May 15, 2026	XML / European Commission Schema	EXPORT READY