


NRC FORM 366 (11-2015)	U.S. NUCLEAR REGULATORY COMMISSION	APPROVED BY OMB: NO. 3150-0104	EXPIRES: 10/31/2018
 LICENSEE EVENT REPORT (LER) (See Page 2 for required number of digits/characters for each block)		Estimated burden per response to comply with this mandatory collection request: 80 hours. Reported lessons learned are incorporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the FOIA, Privacy and Information Collections Branch (T-5 F53), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by e-mail to Infocollects.Resource@nrc.gov, and to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202, (3150-0104), Office of Management and Budget, Washington, DC 20503. If a means used to impose an information collection does not display a currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not required to respond to, the information collection.	
(See NUREG-1022, R 3 for instruction and guidance for completing this form http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1022/r3/)			

1. FACILITY NAME	2. DOCKET NUMBER	3. LER NUMBER		
Cooper Nuclear Station	05000- 298	YEAR 2016	SEQUENTIAL NUMBER - 010	REV NO. - 00

NARRATIVE**CORRECTIVE ACTIONS**

Alarm card FP-1/C-4 was revised to remove taking radwaste valves out of AUTO for each quad. In addition, the applicable procedure has been revised to ensure actions taken will ensure operability is maintained for environmentally qualified components in each of the Reactor Building quads; and a review of fire panel alarm cards will be performed for similar occurrences where monitoring is the only action taken.

PREVIOUS EVENTS

There have been no recent reportable events related to inadequate internal flooding protection compensatory measures.