











| Master data | | |
|----------------|------------|--|
| Customer no. | Report no. | 20230125145033 |
| Customer name | Company | Gossen Metrawatt Südwestpark 15 90449 Nürnberg |
| Representative | Inspector | Wilfred van den berg |

| Testdevice | | |
|------------------|----------|---------------|
| Testdevice ident | 11572400 | Designation |
| Manufacturer | | Serial number |
| Type | | Notice |
| Cost center | | Department |

| Reporting | |
|--------------------|--------------------------|
| Next reporting | 1/2/2024 |
| Utilized measuring | SecuTest S4 BL5710890004 |

| Classifications | |
|------------------|-------------|
| Name | Value |
| Protection class | Class II |
| Connection | test socket |
| Meas. Mode | Passive |

| Measured Values | | 1/2/2023 10:55 AM | |  |
|-----------------------|------------------|-------------------|-------------|---|
| Measurement step name | Measurement name | Measured value | Limit value | Passed |
| Visuele insp. | Sight check | | |  |
| RISO SK II | RINS | >300 MΩ | ≥2.00 MΩ |  |
| IT Alt. | IT≈ | 11 μA | ≤500 μA |  |
| Functietest | P | 0 W | |  |
| Functietest | S | 0 VA | |  |
| Functietest | PF | 1.00 | |  |
| Functietest | I | 0.00 A | |  |
| Functietest | U | 235.4 V | |  |
| Functietest | f | 50.0 Hz | |  |

| Signature | | | | | |
|----------------|------|-----------|--------------------|------|-----------|
| Representative | | | Inspector | | |
| 1/25/2023 | | | Nürnberg 1/25/2023 | | |
| Location | Date | Signature | Location | Date | Signature |